OMRON

Industrial PC Platform NY-series IPC RTOS Controller Industrial Box PC

Hardware User's Manual

NYB1C-31A81 NYB1C-31A91 NYB1C-31AC1 NYB1C-31AK1 NYB1C-31B81 NYB1C-31B91 NYB1C-31BC1 NYB1C-31BK1

Industrial Box PC





W581-E2-05

NOTE -

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form, or by any means, mechanical, electronic, photocopying, recording, or otherwise, without the prior written permission of OMRON.

No patent liability is assumed with respect to the use of the information contained herein. Moreover, because OMRON is constantly striving to improve its high-quality products, the information contained in this manual is subject to change without notice. Every precaution has been taken in the preparation of this manual. Nevertheless, OMRON assumes no responsibility for errors or omissions. Neither is any liability assumed for damages resulting from the use of the information contained in this publication.

Trademarks -

- Sysmac and SYSMAC are trademarks or registered trademarks of OMRON Corporation in Japan and other countries for OMRON factory automation products.
- Windows, Visual Basic and Visual Studio are either registered trademarks or trademarks of Microsoft Corporation in the USA and other countries.
- · Linux is a trademark or registered trademark of Linus Torvalds in Japan and other countries.
- VxWorks is a trademark or registered trademark of Wind River Systems, Inc. in the USA and other countries.
- EtherCAT® is registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany.
- ODVA, CIP, CompoNet, DeviceNet, and EtherNet/IP are trademarks of ODVA.
- The SD and SDHC logos are trademarks of SD-3C, LLC.
- Intel, the Intel Logo, Celeron, Intel Core and Wind River are trademarks or registered trademarks of Intel Corporation or its subsidiaries in the USA and other countries.

Other company names and product names in this document are the trademarks or registered trademarks of their respective companies.

Introduction

Thank you for purchasing the IPC RTOS Controller.

This manual contains information that is necessary to use the IPC RTOS Controller (hereafter also named as Box PC). Please read this manual and make sure you understand the functionality and performance of the Box PC before attempting to use it.

Keep this manual in a safe place where it will be available for reference during operation.

Intended Audience

This manual is intended for the following personnel, who must also have knowledge of electrical systems (an electrical engineer or the equivalent).

- Personnel in charge of introducing Factory Automation systems.
- Personnel in charge of designing Factory Automation systems.
- Personnel in charge of installing and maintaining Factory Automation systems.
- · Personnel in charge of managing Factory Automation systems and facilities.

Applicable Products

This manual covers following IPC RTOS Controller products:

- Products with Windriver Linux 7:
 - NYB1C-31A81
 - NYB1C-31A91
 - NYB1C-31AC1
 - NYB1C-31AK1
- Products with VxWorks 7:
 - NYB1C-31B81
 - NYB1C-31B91
 - NYB1C-31BC1
 - NYB1C-31BK1

Additional Information

Refer to 1-4 Product Configuration on page 1-5 for configuration details.

CONTENTS

Introduction	1
Intended Audience	1
Applicable Products	
Manual Information	7
Page Structure	7
Special Information	8
Terms and Conditions Agreement	9
Warranty, Limitations of Liability	
Application Considerations	
Disclaimers	
Safety Precautions	
Definition of Precautionary Information	
Symbols	
Warnings	
Cautions	15
Precautions for Safe Use	
Disassembly, Dropping, Mounting, Installation and Storage	
Wiring	
Power Supply Design and Turning ON/OFF the Power Supply	
Actual Operation	
Operation	
General Communications	
Battery Replacement Cleaning, Maintenance and Disposal	
Precautions for Correct Use	10
Storage, Installation and Mounting Wiring	
Actual Operation and Operation	
Battery Replacement	
SD Memory Cards	
Regulations and Standards	
Conformance to EU Directives	
Conformance to KC Standards	
Conformance to UL and CSA Standards	
Software Licenses and Copyrights	
Related Manuals	
Related Products Manuals	
Industrial Monitor Manual	
Terminology and Abbreviations	
Industrial PC Platform	
Hardware	
Software	
Revision History	
-	
Sections in this Manual	

Section 1 Overview

1-1	Intended Use	1-2
1-2	Hardware Features	1-3
	ID Information Label 1-3-1 Label with Controller License (Optional)	
1-4	Product Configuration	1-5
	Industrial PC Platform Overview 1-5-1 Industrial Monitor 1-5-2 Industrial Box PC	1-6

Section 2 Hardware

2-1 Com	ponent Names and Functions	
2-1-1	Front and Top of the Industrial Box PC	
2-1-2	Back of the Industrial Box PC	
2-2 LED	Indicators	2-5
2-2-1	PWR LED Indicator	
2-2-2	ERR LED Indicator	
2-2-3	HDD LED Indicator	
2-2-4	RUN LED Indicator	2-6
2-3 Powe	er Button	2-7
2-4 Drive	e Bays	2-8
2-5 SD N	lemory Card Slot	2-9
2-6 PCle	Card Slot	2-10
2-7 Conr	nectors	
2-7-1	Power Connector	
2-7-2	I/O Connector	
2-7-3	USB Connectors	
2-7-4	Ethernet Connectors	
2-7-5	DVI Connector	
2-7-6	RS-232C Connector (Optional)	
2-8 Spar	e Parts	2-15
2-8-1	Battery	
2-8-2	Fan Unit	
2-8-3	Accessory Kit	2-16
2-9 Optio	onal Hardware	2-17
2-9-1	Mounting Brackets	
2-9-2	SD Memory Cards	
2-9-3	USB Flash Drives	2-18
2-9-4	Storage Devices	
2-9-5	DVI Cables	
2-9-6	USB Type-A to USB Type-B Cables	
2-9-7	Industrial Monitor	
2-9-8	Power Supply	
2-9-9	UPS	
2-9-10	UPS Communication Cable	
2-9-11	Recommended EtherCAT Cables	

Section 3 Software

3-1	Available Realtime Operating Systems3	3-2	2
3-1	Available Realtime Operating Systems	,	-

Section 4 Specifications

4-1 Gen	eral Specifications	
4-1-1	Dimensions and Weight	
4-1-2	General Electrical Specifications	
4-1-3	Power Consumption Specifications	
4-1-4	CPU Specifications	
4-1-5	Memory Specifications	
4-1-6	Storage Device Specifications	
4-1-7	PCIe Card Specifications	
4-1-8	Bracket Specifications	
4-2 Con	nector Specifications	
4-2-1	Power Connector Specifications	
4-2-2	I/O Connector Specifications	
4-2-3	USB Connector Specifications	
4-2-4	Ethernet Connector Specifications	
4-2-5	DVI Connector Specifications	
4-2-6	RS-232C Connector Specifications	
4-3 Envi	ironmental Specifications	
4-3-1	Operation Environment Specifications	
4-3-2	Temperature and Humidity Specifications	
4-3-3	Recycling Specifications	

Section 5 Installation

5-1 Unpa	ack	5-2
5-1-1	Unpack Procedure	
5-1-2	Items Supplied	
5-2 Insta	II Options	5-5
5-2-1	Install a Drive	
5-2-2	Install the PCIe Card	5-9
5-3 Mour	nt	5-14
5-3-1	Installation Method in Control Panels	
5-3-2	Product Orientation	5-15
5-3-3	Temperature	5-15
5-3-4	Humidity	5-18
5-3-5	Vibration and Shock	
5-3-6	Atmosphere	5-19
5-3-7	Electrical Environment	
5-3-8	Book Mount Procedure	
5-3-9	Wall Mount Procedure	5-27
5-4 Wire		
5-4-1	Wiring Warnings and Cautions	
5-4-2	Ground	
5-4-3	Wire the Power Connector	
5-4-4	Wire the I/O Connector	5-39
5-5 Conr	1ect	
5-5-1	Connector Identification	
5-5-2	Connection Procedure	
5-6 Initia	I Power ON	5-46
5-6-1	Initial Power ON Procedure	
5-7 Conr	nect UPS	5-48
5-7-1	Connect UPS Using the USB Connector	

Section 6 Operating Procedures

6-1 Pow	er ON	6-2
6-1-1	Power ON Using the Power Button	
6-1-2	Power ON Using the Power ON/OFF Input	
6-1-3	Auto Power ON	6-2
6-2 Pow	er OFF	6-3
6-2-1	Power OFF Using the Operating System Shut Down	
6-2-2	Power OFF Using the Power Button	
6-2-3	Power OFF Using the Power ON/OFF Input	6-4
6-2-4	Forced Power OFF Using the Power Button	6-4

Section 7 Maintenance

7-1 Pre	eventive Maintenance	7-2
7-1-1	Preventive Maintenance Schedule	
7-1-2	Clean the Box PC	7-4
7-1-3	Keep Software Updated	
7-2 Co	rrective Maintenance	7-5
7-2-1	Warning and Error Messages	7-5
7-2-2	Remove the Cover	7-6
7-2-3	Replace the Fan Unit	
7-2-4	Replace the Battery	7-9
7-2-5	Replace a Drive	
7-2-6	Replace the PCIe Card	

Appendices

A-1 BIOS)	A-2
A-1-1	BIOS Overview	A-2
A-1-2	BIOS - Main	A-4
A-1-3	BIOS - Advanced	
A-1-4	BIOS - Chipset	A-9
A-1-5	BIOS - Boot	A-10
A-1-6	BIOS - Security	
A-1-7	BIOS - Save & Exit	A-11
A-2 DVI-I	D Connector Pin Details	A-12
A-3 RS-2	32C Connector Pin Details	A-13


Index

Manual Information

This section provides information about this manual.

Page Structure

The following page structure is used in this manual.



Note: This illustration is provided as a sample. It will not literally appear in this manual.

Item	Explanation	ltem	Explanation
А	Level 1 heading	Е	Special Information
В	Level 2 heading	F	Manual name
С	Level 3 heading	G	Page tab with the number of the main section
D	Step in a procedure	Н	Page number

Special Information

Special information in this manual is classified as follows:



Precautions for Safe Use

Precautions on what to do and what not to do to ensure safe usage of the product.



Precautions for Correct Use

Precautions on what to do and what not to do to ensure proper operation and performance.



Additional Information

Additional information to read as required. This information is provided to increase understanding or make operation easier.



Version Information

Information on differences in specifications and functionality between different versions.

Terms and Conditions Agreement

Warranty, Limitations of Liability

Warranties

Exclusive Warranty

Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.

Limitations

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right.

Buyer Remedy

Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See http://www.omron.com/global/ or contact your Omron representative for published information.

Limitation on Liability; Etc

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

Application Considerations

Suitability of Use

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

Programmable Products

- Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.
- Omron Companies shall not be responsible for the operation of the user accessible operating system (e.g. Windows, Linux), or any consequence thereof.

Disclaimers

Performance Data

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

Change in Specifications

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions

Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

Safety Precautions

Definition of Precautionary Information

The following notation is used in this manual to provide precautions required to ensure safe usage of the IPC RTOS Controller. The safety precautions that are provided are extremely important to safety. Always read and heed the information provided in all safety precautions.

The following notation is used.

	Indicates a potentially hazardous situation which, if not avoid- ed, could result in death or serious injury. Additionally, there may be severe property damage.
Caution	Indicates a potentially hazardous situation which, if not avoid- ed, may result in minor or moderate injury, or property damage.

Symbols

	The circle and slash symbol indicates operations that you must not do. The specific operation is shown in the circle and explained in text. This example indicates prohibiting disassembly.
	The triangle symbol indicates precautions (including warnings). The specific operation is shown in the triangle and explained in text. This example indicates a precaution for electric shock.
$\underline{\land}$	The triangle symbol indicates precautions (including warnings). The specific operation is shown in the triangle and explained in text. This example indicates a general precaution.
0	The filled circle symbol indicates operations that you must do. The specific operation is shown in the circle and explained in text. This example shows a general precaution for something that you must do.

Warnings

Disassembly and Dropping

Do not attempt to disassemble, repair, or modify the product in any way. Doing so may result in malfunction or fire.

Installation

Always connect to a ground of 100 $\boldsymbol{\Omega}$ or less when installing the product.

Ensure that installation and post-installation checks of the product are performed by personnel in charge who possess a thorough understanding of the machinery to be installed.


sary, monitor the power supply voltage on the system for external devices

Fail-safe Measures

Provide safety measures in external circuits to ensure safety in the system if an abnormality occurs due to malfunction of the product or due to other external factors affecting operation. Not doing so may result in serious accidents due to incorrect operation.
Emergency stop circuits, interlock circuit, limit circuits, and similar safety measures must be provided in external control circuits.
Unintended behavior may occur when an error occurs in internal memory of the product. As a countermeasure for such problems, external safety measures must be provided to ensure safe operation of the system.
The use of an uninterruptible power supply (UPS) allows normal operation to continue even if a momentary power failure occurs, possibly resulting in the reception of an erroneous signal from an external device affected by the momentary power failure. Take external fail-safe measures. Where neces-

and use it as an interlock condition.

Actual Operation




Cautions

▲ Caution

Wiring

The product has an internal non-isolated DC power supply. Circuit ground (0 VDC) and frame ground are connected together. When connecting a non-isolated device or a non-isolated interface to the product, take appropriate actions to avoid communication failures or damage to the mentioned ports.



Precautions for Safe Use

Disassembly, Dropping, Mounting, Installation and Storage

- Do not drop the product or subject it to abnormal vibration or shock. Doing so may result in product malfunction or burning.
- When unpacking, check carefully for any external scratches or other damages. Also, shake the product gently and check for any abnormal sound.
- Always use the devices specified in the relevant manual.
- The product must be installed in a control panel.
- Always install equipment that is included in the product specifications. Not doing so may result in failure or malfunction.
- If the storage period exceeds 6 months, check the performance of the Fan Unit before production starts.
- Install the product in the correct orientation and temperature according to the specifications in the manual to prevent overheating. Not doing so may result in malfunction.
- When connecting peripheral devices to the product, ensure sufficient countermeasures against noise and static electricity during installation of the peripheral devices.

Wiring

- Follow the instructions in the manual to correctly perform connector wiring and insertion. Doublecheck all wiring and connector insertion before turning ON the power supply.
- Always ensure connectors, cables, PCIe Cards and Storage devices are completely locked in place to prevent accidental disconnection.
- Before you connect a computer to the product, disconnect the power supply plug of the computer from the AC outlet. Also, if the computer has an FG terminal, make the connections so that the FG terminal has the same electrical potential as the product. A difference in electrical potential between the computer and the product may cause failure or malfunction.
- Do not bend or pull the cables beyond normal limit. Do not place heavy objects on top of the cables or other wiring lines. Doing so may break the cables.
- Always use power supply wires with sufficient wire diameters to prevent voltage drop and burning. Make sure that the current capacity of the wire is sufficient. Otherwise, excessive heat may be generated. When cross-wiring terminals, the total current for all the terminals will flow in the wire. When wiring cross-overs, make sure that the current capacity of each of the wires is not exceeded.
- Be sure that all mounting bracket screws and cable connector screws are tightened to the torque specified in the relevant manuals. The loose screws may result in fire or malfunction.
- Use crimp terminals for wiring.
- For an NY Monitor Link connection, always follow the cable type and connection method specifications in the manual. Otherwise, communications may be faulty.

Power Supply Design and Turning ON/OFF the Power Supply

- Always use a power supply that provides power within the rated range.
- Do not perform a dielectric strength test.

- Always use the recommended uninterruptible power supply (UPS) to prevent data loss and other system file integrity issues caused by unexpected power interruption. Back up the system files in the planned way to prevent data loss and other system file integrity issues caused by incorrect operation.
- Use an Omron S8BA UPS with the correct revision number to prevent improper system shutdown.
- Power ON after the DVI or NY Monitor Link cable is connected between the product and an external monitor.
- Always check the power supply and power connections before applying power. Incorrect power connections can damage the product or cause burning.
- · Always turn OFF the power supply to system before you attempt any of the following.
 - Inserting or removing PCIe Cards
 - Connecting cables
 - · Connecting or disconnecting the connectors
 - Wiring the system
 - Replacing or removing the HDD/SSD
 - Replacing the Battery
 - · Replacing the Fan Unit

Actual Operation

- Choose a OS password that is not obvious to prevent unauthorized access.
- · Remember the OS user name and password. The product is inaccessible without it.
- Before operating the system , please make sure the appropriate software is installed and configured. Doing so may prevent unexpected operation.
- Install all updates and ensure the browser stays up-to-date.
- Install all updates and ensure the firewall stays up-to-date.
- Make sure that your OS environment is protected against malicious software and viruses.
- Install all updates and ensure virus definitions stay up-to-date.
- Do not remove the fan cover while the power is ON. Contact with a rotating fan may result in injury.
- Virtual memory settings can affect the performance of the system. Disable the paging file after installation of applications or updates.
- Correctly perform wiring and setting, and ensure that the shutdown by the UPS can be executed.
- Always use the SMART monitoring feature for storage devices that do not comply to the Omron Storage Device Specifications. Monitor the operating temperature and vibrations to ensure they stay within the environmental specifications of the storage device.

Operation

- Do not carry out the following operations when accessing a USB device or an SD Memory Card.
 - Turn OFF the power supply of the product.
 - Press the Power Button of the product.
 - Remove a USB device or SD memory card.
- Do not attempt to remove or touch the fan unit while the product is powered ON or immediately after the power supply is turned OFF. If you attempt to replace the fan unit then, there is a risk of personal injury due to hot or rotating parts.
- Press the power button for several seconds to force the product shutdown. Always back up files in the planned way to prevent data loss or system file corruption.

• Do not touch any product housing when power is being supplied or immediately after the power supply is turned OFF. Doing so may result in burn injury.

General Communications

· Separate the machine network segment from the office network to avoid communication failures.

Battery Replacement

- Dispose of any Battery that has been dropped on the floor or otherwise subjected to excessive shock. Batteries that have been subjected to shock may leak if they are used.
- UL standards require that only an experienced engineer replace the Battery. Make sure that an experienced engineer is in charge of Battery replacement.
- The Battery may leak, rupture, heat, or ignite. Never short-circuit, charge, disassemble, heat, or incinerate the Battery or subject it to strong shock.

Cleaning, Maintenance and Disposal

- Do not use corrosive substances to clean the product. Doing so may result in the failure or malfunction.
- Dispose of the product and batteries according to local ordinances as they apply.



• The following information must be displayed for all products that contain primary lithium batteries with a perchlorate content of 6 ppb or higher when shipped to or transported through the State of California, USA.

Perchlorate Material - special handling may apply.

See http://www.dtsc.ca.gov/hazardouswaste/perchlorate.

• The product contains a lithium battery with a perchlorate content of 6ppb or higher. When exporting an end product containing the product to or shipping through California, USA, label all packing and shipping containers appropriately.

Precautions for Correct Use

Storage, Installation and Mounting

- Do not operate or store the product in the following locations. Operation may stop or malfunctions may occur.
 - · Locations subject to direct sunlight
 - · Locations subject to temperatures or humidity outside the range specified in the specifications
 - · Locations subject to condensation as the result of severe changes in temperature
 - · Locations subject to corrosive or flammable gases
 - · Locations subject to dust (especially iron dust) or salts
 - · Locations subject to exposure to water, oil or chemicals
 - · Locations subject to shock or vibration
 - · Locations outdoors subject to direct wind and rain
 - · Locations subject to strong ultraviolet light
- Always install the product with sufficient surrounding space to allow for adequate heat dissipation and cooling effect.
- Take appropriate and sufficient countermeasures when installing the product in the following locations
 - · Locations subject to strong, high-frequency noise
 - · Locations subject to static electricity or other forms of noise
 - · Locations subject to strong electromagnetic fields
 - · Locations subject to possible exposure to radioactivity
 - Locations close to power lines
- Always touch a grounded piece of metal to discharge static electricity from your body before starting an installation or maintenance procedure.
- Insert USB devices and PCIe devices correctly to avoid the burning, failure or malfunction.
- Execute a backup of the product before PCIe addition or replacement. Be sure that the PCIe device works correctly before you use them for actual operation. PCIe devices and their related software may cause an OS boot failure or crash.
- Ensure the selected operating system supports ACPI to enable operating system shutdown using the power button.
- Download the enhanced Video Driver from the OMRON Download Center and install it on the Industrial PC.

Wiring

- Always ensure the rated supply voltage is connected to the product.
- Do not allow wire clippings, shavings, or other foreign material to enter the product. Otherwise, burning, failure, or malfunction may occur. Cover the product or take other suitable countermeasures, especially during wiring work.
- Do not use cables exceeding the maximum specified length. Doing so may cause malfunction.
- Do not connect an AC power supply to the DC power connector.
- Observe the following precautions to prevent broken wires.
 - When you remove the sheath, be careful not to damage the conductor.
 - Connect the conductor without twisting the wires.

• Do not weld the conductors. Doing so may cause the wires to break with vibration.

Actual Operation and Operation

- After an OS update or a peripheral device driver update for the product is executed, the product behavior might be different. Confirm that operation is correct before you start actual operation.
- Always create a Windows System Repair Disk using Windows Backup and Restore to recover the HDD/SSD configuration if necessary.
- Ensure the fan is operational to provide adequate cooling while the power is turned ON.
- HDD and SSD storage devices, SD Memory Cards, power buttons, fan units and batteries have finite lives and if those are exceeded, the product may fail or malfunction.
- Always monitor the fan status. If a fan is used beyond its service life, the *Low Revolution Speed* warning message is displayed and the product overheating may occur.
- Always monitor the battery warning message. When a battery has low voltage, the system time will be lost.
- If the product experiences a sudden loss of power or disconnecting the cable while saving a setting or transfer of data is underway, the changes may not be stored and unexpected behavior may occur.
- Ensure that available software checks are performed by personnel in charge who possess a thorough understanding of the software.
- Diagnostic information is not available when the Industrial PC Support Utility is not installed.

Battery Replacement

- Turn ON the power after replacing the battery for a product that has been unused for an extended period of time. Leaving the product unused without turning ON the power even once after the battery is replaced may result in a shorter battery life.
- Make sure to use a battery of the correct type, install the battery properly.
- Apply power for at least five minutes before changing the battery. Mount a new battery within five minutes after turning OFF the power supply. If power is not supplied for at least five minutes, the clock data may be lost. Check the clock data after changing the battery.

SD Memory Cards

• Insert an SD Memory Card completely and ensure it is in place.

Regulations and Standards

Conformance to EU Directives

The IPC RTOS Controller complies with EU Directives. To ensure that the machine or device in which the IPC RTOS Controller is used complies with EU Directives, the following precautions must be observed:

- The IPC RTOS Controller must be installed within a control panel.
- The IPC RTOS Controller that complies with EU Directives also conforms to the Common Emission Standard. Radiated emission characteristics (10-m regulations) may vary depending on the configuration of the control panel used, other devices connected to the control panel, wiring, and other conditions. You must therefore confirm that the overall machine or equipment in which the IPC RTOS Controller is used complies with EU Directives.
- This is a Class A product (for industrial environments). In a residential environment, it may cause radio interference. If radio interference occurs, the user may be required to take appropriate measures.

Applicable Directive

EMC Directive

EMC Directive

OMRON devices that comply with EU Directives also conform to the related EMC standards so that they can be more easily built into other devices or the overall machine. The actual products have been checked for conformity to EMC standards.

Applicable EMC (Electromagnetic Compatibility) standards are as follows:

- EMS (Electromagnetic Susceptibility): EN 61131-2
- EMI (Electromagnetic Interference): EN 61131-2 (Radiated emission: 10-m regulations)

Whether the products conform to the standards in the system used by the customer, however, must be checked by the customer. EMC-related performance of the OMRON devices that comply with EU Directives will vary depending on the configuration, wiring, and other conditions of the equipment or control panel on which the OMRON devices are installed. The customer must, therefore, perform the final check to confirm that devices and the overall machine conform to EMC standards.

Conformance to KC Standards

When you use this product in South Korea, observe the following precautions.

사용자안내문		
이 기기는 업무용 환경에서 사용할 목적으로 적합성평가를 받은		
기기로서 가정용 환경에서 사용하는 경우 전파간섭의 우려가 있습니다.		

This product meets the electromagnetic compatibility requirements for business use. There is a risk of radio interference when this product is used in home.

Conformance to UL and CSA Standards

Some Industrial PC Platform products comply with UL and CSA standards. If you use a product that complies with UL or CSA standards and must apply those standards to your machinery or devices, refer to this manual. This manual provides the application conditions for complying with the standards. If the product is used in a manner not specified in the Instruction Sheet or in the product manuals then the protection provided by the equipment may be impaired.

Software Licenses and Copyrights

This product incorporates certain third party software. The license and copyright information associated with this software is available at http://www.fa.omron.co.jp/nj_info_e/.

Related Manuals

The following manuals are related. Use these manuals for reference.

Manual name	Cat. No.	Model num- bers	Application	Description
UPS S8BA User's Manual	U702	S8BA	Learning the information that is necessary to use the Uninterruptible Pow- er Supply (UPS) Unit.	An introduction to the UPS is provided along with the following information: • Overview • Preparation • Installation and Connection • Check and Start Operation • Maintenance and Inspection • Shutdown Processing • I/O Signal Functions • Troubleshooting
UPS Setting Utili- ty Instruction Manual		• SB8A • BU-2RWL	Learning the information that is necessary to con- nect the UPS and to con- figure all settings.	 An introduction to the UPS Setting Utility is provided along with the following information: Overview Operating Environment Software License Agreement Connect Use the UPS Setting Utility Setting Details
UPS Power Attendant Lite for Win- dows User's Manual		S8BA	Learning the information that is necessary to use the software to monitor, test and control the UPS and to configure all set- tings.	 An introduction to the software is provided along with the following information: Overviews Connection and Installation The Simple Usage and Operation Test Settings

Related Products Manuals

Industrial Monitor Manual

This table contains the related manual of the Industrial Monitor.

Manual name	Cat. No.	Model numbers	Application	Description
Industrial Monitor Us- er's Manual	W554	NYM15W-C100□ NYM15W-C106□ NYM12W-C100□ NYM12W-C106□	Learning all basic infor- mation about the Indus- trial Monitor. This in- cludes introductory in- formation with features, hardware overview, specifications, mount- ing, wiring, connecting, operating and maintain- ing the Industrial Moni- tor.	An introduction to the Industrial Monitor is provided along with the following information: • Overview • Hardware • Software • Specifications • Installation • Operating Proce- dures • Maintenance

Terminology and Abbreviations

Industrial PC Platform

Term / Abbreviation	Description
Industrial PC Platform	An integrated range of OMRON products designed for use in any industrial applica-
	tion that will benefit from advanced PC technology
Industrial Monitor	An industrial monitor with a touchscreen as the user interface designed to work in
	industrial environments
Industrial Panel PC	An industrial PC with an integrated touchscreen monitor designed to work in indus-
	trial environments
Industrial Box PC	A box-shaped industrial PC including an OS designed to work in industrial environ-
	ments
IPC	Industrial PC
Sysmac	OMRON's brand name of the product family for the industrial automation equip-
	ment

Hardware

Term / Abbreviation	Description
BMC	Board Management Controller
CPU	A Central Processing Unit is the hardware within a computer that executes the in-
	structions of a computer program
DVI	Digital Visual Interface
DVI-D	A Digital Visual Interface with only Digital signals
DVI-I	A Digital Visual Interface with Analog and Digital signals
Ethernet	A network communication protocol used in TCP/IP network
HDD	A Hard Disk Drive storage device
HMI	A Human Machine Interface that facilitates machine operation and control
iMLC	Industrial Multi-Level Cell type of SSD storage device
NYML	NY Monitor Link interface with video signals and USB signals
PCle	The PCI Express is a high-speed computer bus standard called Peripheral Compo-
	nent Interconnect Express
SATA	The Serial AT Attachment is a serial bus interface primarily used with mass storage
	devices such as hard disk drives
SLC	Single-Level Cell type of SSD storage device
SO-DIMM	Small Outline Dual Inline Memory Module
SSD	A Solid State Drive storage device
USB	Universal Serial Bus

Software

Term / Abbreviation	Description
ACPI	Advanced Configuration and Power Interface protocol for operating systems
API	Application Programming Interface
BIOS	Basic Input Output System. The first software run by a PC when powered on.
Developer	Any person involved with the development of software
DST	Daylight Saving Time
EWF	Enhanced Write Filter
FBWF	File-Based Write Filter
lloT	Industrial Internet of Things
Linux	An open source Operating System
MBR	Master Boot Record
Merge module	A module providing a standard method by which developers deliver shared Win-
	dows installer components and setup logic to their applications
MSDN	Microsoft Developer Network
NUI	Natural User Interface
OS	Operating System
PLC	Programmable Logic Controller
RTOS	Realtime Operating System
SDK	Software Development Kit
TCP/IP	Transmission Control Protocol / Internet Protocol, a core member of the Internet
	protocol suite
TPM	Trusted Platform Module
VxWorks	A Realtime Operating System designed by Wind River
Windows	An Operating System designed by Microsoft

Revision History


A manual revision code appears as a suffix to the catalog number on the front and back covers of the manual.



- Revision code

Revision code	Date	Revised content
05	July 2019	Updated Conformance to KC certification
03	July 2017	 Added Storage Device Considerations Added 2 preventive maintenance actions Modified UPS configuration procedure Several minor modifications
02	December 2016	UL implementationMinor modifications
01	August 2016	Original production

Sections in this Manual



1

Overview

This section provides general information about the IPC RTOS Controller.

1-1	Intended Use1			
1-2	2 Hardware Features			
1-3	ID Information Label			
	1-3-1 Label with Controller License (Optional)	1-4		
1_1	Product Configuration	1_5		
1	Product Configuration	1-5		
1-5	Industrial PC Platform Overview			
	-	1-6 1-6		

1-1 Intended Use

The IPC RTOS Controller (also indicated as Box PC) is an industrial-grade PC intended for use within factory automation environments. This Box PC simultaneously uses the standard realtime operating system and programs as well as third party software to serve as a powerful PC platform. The IPC RTOS Controller has a compact design that offers flexibility, expandability and easy maintenance for applications in factory automation environments.

1-2 Hardware Features

The Industrial Box PC provides the following hardware features:

- Compact design with two mounting orientation options
- The Box PC has a compact design to minimize panel space while allowing for two mounting orientations.
- Powerful CPU options

Powerful CPU options provide high performance for various applications.

- Fanless cooling for multiple CPU types
 The Box PC has passive cooling for multiple CPU types which means no moving parts and less maintenance effort.
- Easy access to storage devices and the PCI Express Card Adding or changing storage devices (HDD, SSD) and PCI Express Card is fast and simple.
- LED indicators LED indicators provide a clear indication of the operational status of the Box PC.
- DVI visual interface
 The video interface for the Box PC is provided with a DVI connector for connection to a monitor.
 An extra (optional) DVI interface is available for connection to a second monitor.
- NY Monitor Link interface
 The interface combines video signals and USB signals for a connection to an OMRON Industrial Monitor using a single NY Monitor Link cable up to 100 meter.
- 3 Ethernet ports 1Gb/s
- Interface with multiple networks.
- Built-in I/O

Built-in I/O for UPS status and Box PC shutdown control are provided.

• 4 USB ports

2 USB2.0 ports and 2 USB3.0 ports are provided for connection to external USB devices such as keyboards, memory sticks, or other peripheral hardware.


Built-in SD Memory Card slot

An SD Memory Card slot is provided for removable memory.

1

1-3 ID Information Label

The ID information label contains relevant information about the IPC RTOS Controller. The following example will be different from your product label.



ltem	Name	Description	
А	Product name	The name of your product	
В	Model *1	Model and configuration details	
С	Power rating	Power rating details	
D	Custom ID	A custom ID [NYC	
	(Optional)	Only for Industrial Monitors and Industrial Panel PCs with a custom logo *1.	
E	Standards and QR code	The applicable standards and a QR code for OMRON internal use	
F	LOT number and serial number	 Production details, consisting of: The lot number of the IPC RTOS Controller in the format DDMYY□. DDMYY with Month number 1 to 9 for January to September, X for October, Y for November, and Z for December. □: For use by OMRON Serial number (4 digits) 	
G	MAC ADDRESS *2	 PORT 1: the MAC address of Ethernet port 1 PORT 2: the MAC address of Ethernet port 2 PORT 3: the MAC address of Ethernet port 3 	

*1. Refer to 1-4 Product Configuration on page 1-5 for model details.

*2. Refer to 4-2-4 Ethernet Connector Specifications on page 4-15 for Ethernet specifications.



Additional Information

Refer to 2-1-2 Back of the Industrial Box PC on page 2-4 for the ID label location.

1-3-1 Label with Controller License (Optional)

This license label contains the license key for the Industrial PC with Programmable Multi Axis Controller.



1-4 Product Configuration

This section provides an overview of the product configurations available for the IPC RTOS Controller. The product configuration is visible in the model-type that is mentioned on the ID information label of the product.

ΝΥΕ	3 🗆 🗆 -	- 🗆				
1	2	3	4	5	6	7

Item	Description	Option / Description
1	Series name	NY: NY-series Industrial Box PC
2	Processor	1C: Intel [®] Celeron [®] 2980U 4th generation CPU with fanless cooling
3	Main memory	3: 8 GB, Non-ECC
4	Expansion slots	1: 1 PCIe slot
5	Operating system	A: Windriver Linux 7 (with EtherCAT Master) B: VxWorks 7 (with EtherCAT Master)
6	Storage	8: 32 GB, SSD SLC 9: 64 GB, SSD SLC C: 320 GB, HDD K: 128 GB, SSD iMLC
7	Interface	1: RS-232C

1

1-5 Industrial PC Platform Overview

The Industrial PC Platform is an integrated range of products designed for use in a variety of industrial applications that will benefit from advanced PC technology. The range is scalable, robust and reliable, and is suitable for use with both standard operating system software and proprietary programs for machine control and automation.

In line with OMRON's established quality standards, each element in the Industrial PC Platform, ranging from the standalone Industrial Box PC to the touchscreen Industrial Monitor, is engineered with long-life components and built to the most advanced design standards.

The following sections introduce Industrial PC Platform products.

1-5-1 Industrial Monitor

The Industrial Monitor is of key importance at the interface between operator and system. The Industrial Monitor is efficient, effective and highly visible with an attractive design.

Using smart algorithms, the touch controller determines the exact location of each touch for precise control as well as detecting abnormal or illegal actions to protect misuse or false touches.



1-5-2 Industrial Box PC

The Industrial Box PC is designed to meet the specific needs of the industrial environment. Design simplification and future-proof architecture minimize the risk of failure. In addition, new PC features can be seamlessly incorporated, without the need for wholesale redesign.



1

1 Overview

2

Hardware

This section provides an overview of the hardware of the IPC RTOS Controller.


2-1	Comp	onent Names and Functions	2-2
	2-1-1	Front and Top of the Industrial Box PC	
	2-1-2	Back of the Industrial Box PC	
2-2	LED Ir	ndicators	
	2-2-1	PWR LED Indicator	
	2-2-2	ERR LED Indicator	
	2-2-3	HDD LED Indicator	
	2-2-4	RUN LED Indicator	
2-3	Power	r Button	2-7
2-4	Drive	Bays	2-8
2-5	SD Me	emory Card Slot	2-9
2-6	PCle (Card Slot	2-10
2-7	Conne	ectors	
	2-7-1	Power Connector	
	2-7-2	I/O Connector	
	2-7-3	USB Connectors	
	2-7-4	Ethernet Connectors	
	2-7-5	DVI Connector	
	2-7-6	RS-232C Connector (Optional)	
2-8	Spare	Parts	2-15
	2-8-1	Battery	
	2-8-2	Fan Unit	
	2-8-3	Accessory Kit	
2-9	Optio	nal Hardware	2-17
	2-9-1	Mounting Brackets	
	2-9-2	SD Memory Cards	
	2-9-3	USB Flash Drives	
	2-9-4	Storage Devices	
	2-9-5	DVI Cables	
	2-9-6	USB Type-A to USB Type-B Cables	
	2-9-7	Industrial Monitor	
	2-9-8	Power Supply	
	2-9-9 2-9-10	UPS UPS Communication Cable	
	2-9-10 2-9-11	Recommended EtherCAT Cables	
	2-3-11		

2-1 Component Names and Functions

This section shows views of the IPC RTOS Controller with information about all items.

2-1-1 Front and Top of the Industrial Box PC

This section shows the component names and functions for the front and top of the Box PC.



ltem	Name	Description	
А	Cover	Provides access to:	
		The battery	
		 The fans (only for Box PCs that have active cooling) 	
		The battery replacement date	
		The license key for the operating system (optional)	

ltem	Name	Description
В	Option port	Interface connection options for peripheral devices or an additional monitor:
		RS-232C connector
		or
		DVI-D connector
		or
		NYML connector
С	SD Memory Card slot	SD Memory Card slot
D	PCIe bay	PCI Express mounting slot
E	DVI connector	Digital Visual Interface connector
F	10BASE-T/100BASE-	3 RJ45 Gb Ethernet interface connectors
	TX/1000BASE-T	
	Ethernet connectors	
G	USB 2.0 connectors	2 USB 2.0 interface connectors
Н	USB 3.0 connectors	2 USB 3.0 interface connectors
I	Drive bays ^{*1}	Two 2.5 inch drive bays for HDD/SSD storage devices:
		• Drive bay A = Bay for an optional drive ^{*2} for the operating system and
		main storage
		Drive bay A is the bay at the side of the connectors
		 Drive bay B = Bay for an optional drive ^{*2} for additional storage
		Drive bay B is the bay at the outside of the Box PC
J	I/O connector	2 inputs (Power ON/OFF Input and UPS Mode Input) and 1 output (Power
		Status Output)
К	LED indicators	Visual indicators for the operating state of the IPC RTOS Controller
L	Power button	Pushbutton to manually power ON/OFF the Box PC
М	Power connector	Lockable power connector

*1. Depending on the model one or two drives are supported.

Refer to 4-1-4 CPU Specifications on page 4-5 for the number of supported drives.


*2. Installed storage and the operating system are depending on the configuration.

Refer to 1-4 Product Configuration on page 1-5 for:

- installed drive (storage) details
- operating system details

2-1-2 Back of the Industrial Box PC

This section shows the component names and functions for the back of the Industrial Box PC.



Item	Name	Description
A	ID information label	Label containing Model ID., LOT No. and other product specific information. *1
В	License label	Optional label containing the license number. Only available on Industrial PC with Programmable Multi Axis Controller models. *1 *2


*1. Refer to 1-3 ID Information Label on page 1-4 for label details.

*2. Refer to 1-4 Product Configuration on page 1-5 for configuration details.

2-2 LED Indicators

The Industrial Box PC has two rows of four LED indicators that show the operating status of the product. Both rows have the same function.

The following LED indicators are available:



Item	LED Indicator	Name	Description
А	PWR	Power	Indicates the operating mode of the Industrial Box PC.
В	ERR	Error	Indicates the presence and type of an error.
С	HDD	Hard Disk Drive	Indicates HDD/SSD activity.
D	RUN	Run	Indicates the status of a user-defined function. *1
*1 Not			

*1. Not for products NY512-A . Refer to *1-4 Product Configuration* on page 1-5 for configuration details.

2-2-1 PWR LED Indicator

The Power LED (PWR) indicates the operating mode of the Box PC.

Color	Sta	itus	Meaning
Green		Not lit	There is no power supplied or the Box PC is OFF.
		Blinking	Power is currently supplied and the Box PC is in stand-by mode.
		Lit	Power is currently supplied and the Box PC is turned ON.

2-2-2 ERR LED Indicator

The Error LED (ERR) indicates the presence and type of an error within the Box PC.

Color	Sta	itus	Meaning
Red		Not lit	The 24 VDC power is not supplied
			No error is present
		Blinking	Fan Error
			Battery low
		Lit	Thermal shutdown
			Watchdog Error
			 Power Supply undervoltage error
			 Power Supply overvoltage error
			Power supply defective



Additional Information

- Refer to 7-2 Corrective Maintenance on page 7-5 for actions to solve errors.
- For a Box PC with a Windows operating system the status of this LED can be defined by users using the Industrial PC System API.

Refer to NY-series Industrial Box PC User's Manual (Cat. No. W553) for Industrial PC System API details.

2-2-3 HDD LED Indicator

The Hard Disk Drive LED (HDD) indicates activity of the HDD or SSD.

Color	Sta	tus	Meaning
Yellow		Flickering	The HDD or SSD is active.

2-2-4 RUN LED Indicator

The RUN LED has no functionality and will not be lit.




Additional Information

For a Box PC with a Windows operating system the status of this LED can be defined using the Industrial PC System API.

Refer to NY-series Industrial Box PC User's Manual (Cat. No. W553) for Industrial PC System API details.

2-3 Power Button

The power button is used to manually switch the Box PC ON and OFF.






- Refer to 6-1 Power ON on page 6-2 for ON details.
- Refer to 6-2 Power OFF on page 6-3 for OFF details.

2-4 Drive Bays

The drive bays in the IPC RTOS Controller accept 2.5 inch Hard Disk Drives (HDD) or Solid State Drives (SSD). Depending on the model one or two drives are supported.






- Refer to 4-1-4 CPU Specifications on page 4-5 for the number of supported drives.
- Refer to 4-1-6 Storage Device Specifications on page 4-6 for storage device specifications.
- Refer to 5-2-1 Install a Drive on page 5-5 for install information.
- Refer to 7-2-5 Replace a Drive on page 7-11 for maintenance information.

2-5 SD Memory Card Slot

The SD Memory Card slot on the IPC RTOS Controller accepts SD Memory Cards with the following specifications.

- SDHC type (SD 2.0 specification)
- · Up to 32 GB capacity





Additional Information


Refer to 2-9-2 SD Memory Cards on page 2-17 for SD Memory Card details.

2

2-6 PCIe Card Slot

The PCI Express (PCIe) Card slot of the IPC RTOS Controller accepts various PCIe Cards for specific hardware needs.

The PCIe Card connectors are available behind the cover $\widehat{\mathbb{A}}$ and the PCIe Card is mounted in the PCIe drawer $\widehat{\mathbb{B}}$




- Refer to 4-1-7 PCIe Card Specifications on page 4-8 for specifications.
- Refer to 5-2-2 Install the PCIe Card on page 5-9 for install information.
- Refer to 7-2-6 Replace the PCle Card on page 7-16 for maintenance information.

2-7 Connectors

This section gives an overview of the available connectors for the IPC RTOS Controller.

2-7-1 Power Connector

The power connector on the Box PC is used to supply 24 VDC power to the Box PC. The power connector is supplied with the Box PC.





Additional Information


- Refer to 4-2-1 Power Connector Specifications on page 4-10 for specifications.
- Refer to 5-4-3 Wire the Power Connector on page 5-36 for wiring details.
- Refer to 5-5 Connect on page 5-42 for connection details.

2-7-2 I/O Connector

The I/O connector on the IPC RTOS Controller provides discrete signals with the following functions.

- Input signal to the Box PC when a connected UPS switches to battery power.
- Input signal to the Box PC to perform a shutdown or power ON when the signal turns ON.
- Output signal from the Box PC to indicate the power status of the Box PC.

The I/O connector is supplied with the Box PC.






Additional Information

- Refer to 4-2-2 I/O Connector Specifications on page 4-11 for specifications.
- Refer to 5-4-4 Wire the I/O Connector on page 5-39 for wiring details.
- Refer to 5-5 Connect on page 5-42 for connection details.

2-7-3 USB Connectors

The USB connectors support USB 2.0 and USB 3.0 specifications.

All USB interfaces are protected against overcurrent and all ports support Wake-on-USB.






- Refer to 4-2-3 USB Connector Specifications on page 4-15 for specifications.
- Refer to 5-5 Connect on page 5-42 for connection details.

2-7-4 Ethernet Connectors

The Ethernet connectors provide 3 individual Ethernet ports on the IPC RTOS Controller. Each port offers 10BASE-T/100BASE-TX/1000BASE-T Ethernet speeds.






Additional Information

- Refer to 4-2-4 Ethernet Connector Specifications on page 4-15 for specifications.
- Refer to 5-5 Connect on page 5-42 for connection details.

2-7-5 DVI Connector

The DVI interfaces supported on this connector are dependent on the configuration of the IPC RTOS Controller.






- Refer to 1-4 Product Configuration on page 1-5 for configuration details.
- Refer to 4-2-5 DVI Connector Specifications on page 4-18 for specifications.
- Refer to 5-5 Connect on page 5-42 for connection details.

2-7-6 RS-232C Connector (Optional)

Depending on the product configuration an optional RS-232C connector is available.





- Refer to 1-4 Product Configuration on page 1-5 for configuration details.
- Refer to 4-2-6 RS-232C Connector Specifications on page 4-19 for specifications.
- Refer to 5-5 Connect on page 5-42 for connection details.

2-8 Spare Parts

The following spare parts for the IPC RTOS Controller are available.

2-8-1 Battery

One battery is supplied with the Box PC. The battery supplies power to the real-time clock. The battery is located inside the Box PC.

Model	Appearance	Specifications
CJ1W-BAT01		Service life: 5 years at 25°C



Additional Information

Refer to 7-2-4 Replace the Battery on page 7-9 for the replacement procedure.

2-8-2 Fan Unit

The Fan Unit is available for the Box PC that has active cooling.

Model	Appearance	Specifications
NY000-AF00		 Service life: 70,000 hours of continuous operation at 40°C with 15% to 65% relative humidity Shelf life: 6 months This is the storage limitation with no power supplied. We highly recommend performance testing if the Fan Unit has been stored over 6 months.



Additional Information

Refer to 7-2-3 Replace the Fan Unit on page 7-7 for the replacement procedure.

2-8-3 Accessory Kit

The accessory kit for the Box PC.


Model	Appearance	Specifications
NY000-AK00		 Accessory Kit containing all accessories supplied with the Box PC. Power connector I/O connector Drive bracket for drive installation 4 mounting screws for drive installation PCIe Card support for PCIe Card installation PCIe Card clip for PCIe Card installation

2-9 Optional Hardware

The following optional hardware is available for the IPC RTOS Controller.

2-9-1 Mounting Brackets

Mounting brackets details are provided below.



2-9-2 SD Memory Cards

SD Memory Card details are provided below.

OMRON is not responsible for the operation, performance or write life of any other brand of SD Memory Card.

Model	Appearance	Card type	Capacity	Format
HMC-SD291	omron A MKC-SD291	SD Card	2 GB	FAT16
HMC-SD491		SDHC Card	4 GB	FAT32

2-9-3 USB Flash Drives

USB Flash Drive details are provided below.

OMRON is not responsible for the operation, performance, or write life of any other brand of USB Flash Drives.

Model	Appearance	Capacity	
FZ-MEM2G		2 GB	
FZ-MEM8G	C. March	8 GB	

2-9-4 Storage Devices

Storage device details are provided below.

OMRON is not responsible for the operation, performance, or write life of any other storage device.

Model	Appearance	Storage type	Capacity
NY000-AH00		HDD	320 GB
NY000-AS00		SSD SLC	32 GB
NY000-AS01			64 GB
NY000-AS02		SSD iMLC	128 GB

Additional Information

Refer to 4-1-6 Storage Device Specifications on page 4-6 for storage device specifications.

Storage Device Considerations

For a storage device that is not an OMRON NY000-A

- OMRON is not responsible for the operation, performance or write life of any storage device other than those supplied by OMRON.
- Test and measure the environmental performance of the intended storage device before actual operation, using the SMART monitoring feature of the selected storage device.
- Ensure the temperature and vibrations of the storage device are within the operating temperature specifications and vibration specifications during actual operation.
- Using a storage device with maximum power consumption exceeding 2W is not advised. Ensure that the SMART monitor features of the storage device are used to detect overheating.



- Refer to 4-1-6 Storage Device Specifications on page 4-6 for storage device specifications.
- Refer to 4-3-1 Operation Environment Specifications on page 4-20 for environment specifications, specifically temperature and vibration specifications.

2-9-5 DVI Cables


DVI cable details are provided below.

OMRON is not responsible for the operation or performance of any other brand of DVI cable.

Model	Appearance	Cable length	Specifications
NY000-		2 m	Supports DVI-D
AC00 2M			Minimum bend radius: 36 mm
NY000-		5 m	
AC00 5M			

DVI Cable Clearance

The DVI cable requires a minimum clearance of 90 mm from the connector entry to prevent excessive strain on the connector and cable assembly.



2-9-6 USB Type-A to USB Type-B Cables


USB Type-A to USB Type-B cable details are provided below.

OMRON is not responsible for the operation or performance of any other brand of USB Type-A to USB Type-B cable.

Model	Appearance	Cable length	Specifications
FH-VUAB 2M		2 m	• USB 2.0
FH-VUAB 5M	OF ST	5 m	Minimum bend radius: 25 mm

USB Type-A to USB Type-B Cable Clearance

The USB Type-A to USB Type-B cable requires a minimum clearance of 60 mm from the connector entry to prevent excessive strain on the connector and cable assembly.



2-9-7 Industrial Monitor

Details for the recommended monitor are provided below.

OMRON is not responsible for the operation or performance of any other monitor.

Model	Appearance	Specifications	
NYM15W-C100□ NYM15W-C106□ NYM12W-C100□ NYM12W-C106□		 LCD touchscreen Multi-touch functionality Supply voltage: 24 VDC Up to 1,280 x 800 pixels at 60 Hz 2 USB Type-A Connectors Programmable brightness control 	



Additional Information

Refer to the OMRON website for specifications and manuals.

2-9-8 Power Supply

Details for the recommended power supply are provided below.

OMRON is not responsible for the operation or performance of any other power supply.

Model	Appearance	Specifications
S8VK-G□□□24		Output voltage: 24 VDC



- Refer to 4-1-3 Power Consumption Specifications on page 4-4 for power consumption details.
- Refer to <u>the OMRON website</u> for specifications and manuals of the S8VK-G. Note that the power consumption details of the Box PC determine the minimum power rating of your power supply.


2-9-9 UPS

Details for the recommended UPS are provided below.

OMRON is not responsible for the operation or performance of any other UPS.

Model	Appearance	Specifications	
S8BA with revision number 04 or higher. *1		Output voltage during backup oper- ation: 24 VDC±5%	

*1. The revision number of the UPS can be retrieved from the serial number label on the product and the product packaging.



ltem	Description
1	Product code
2	Product period and sequential number
3	Revision number
4	RoHS status

Precautions for Safe Use

Use an Omron S8BA UPS with the correct revision number to prevent improper system shutdown.

Additional Information

- Refer to 2-9-8 Power Supply on page 2-20 for power supply details.
- Refer to 4-1-3 Power Consumption Specifications on page 4-4 for power consumption details.
- Refer to <u>the OMRON website</u> for S8BA specifications or to the UPS S8BA User's Manual (*Cat. No. U702*) for the UPS manual.

Note that the power consumption details determine the output current/capacity of your UPS.

2-9-10 UPS Communication Cable

Communication cable details are provided below.

OMRON is not responsible for the operation or performance of any other brand of communication cable.

Model	Appearance	Cable length	Specifications
S8BW-C02		2 m	Signals forSignal output (BL, TR, BU, WB)Remote ON/OFF inputUPS Stop Signal input (BS)

2-9-11 Recommended EtherCAT Cables

For EtherCAT, use Straight STP (shielded twisted-pair) cable of category 5 or higher with double shielding (braiding and aluminum foil tape).

The following table lists wiring materials used for the EtherCAT communications cables.

	Product		Manufacturer	Cable length [m]	Model
Cables with con- nectors		Standard type Cable with Con-	OMRON	0.3	XS6W-6LSZH8 SS30CM-Y
	AWG27 × 4P. Cable color :	: Ends (RJ45/		0.5	XS6W-6LSZH8 SS50CM-Y
	Yellow *1 *2	RJ45)		1	XS6W-6LSZH8 SS100CM-Y
		\$		2	XS6W-6LSZH8 SS200CM-Y
				3	XS6W-6LSZH8 SS300CM-Y
				5	XS6W-6LSZH8 SS500CM-Y
	Size and num- ber of pairs:	Rugged type Cables with	OMRON	0.3	XS5W-T421- AMD-K
	AWG22 × 2P.Connectors onCable color :Both EndsBlue *1(RJ45/RJ45)	Both Ends	th Ends	0.5	XS5W-T421- BMD-K
		(RJ45/RJ45)		1	XS5W-T421- CMD-K
		*0		2	XS5W-T421- DMC-SS
				5	XS5W-T421- GMC-SS
				10	XS5W-T421- JMC-SS
	Size and num- ber of pairs:	Rugged type Cables with	OMRON	0.5	XS5W-T421- BM2-SS
	AWG22 × 2P. Cable color :	Connectors on Both Ends (M12		1	XS5W-T421- CM2-SS
	Black *3	Straight/M12 Straight)		2	XS5W-T421- DM2-SS
	0		3	XS5W-T421- EM2-SS	
			5	XS5W-T421- GM2-SS	
				10	XS5W-T421- JM2-S

	Product		Manufacturer	Cable length [m]	Model
Cables with con- nectors ^{*4}	Size and num- ber of pairs:	Rugged type Cables with	OMRON	0.5	XS5W-T421- BMC-SS
	AWG22 × 2P. Cable color :	Connectors on Both Ends (M12 Straight/RJ45)		1	XS5W-T421- CMC-SS
	Black *3 Straight/RJ			2	XS5W-T421- DMC-SS
		OPP O		3	XS5W-T421- EMC-SS
				5	XS5W-T421- GMC-SS
				10	XS5W-T421- JMC-SS
Cables / Con- nectors	Size and num- ber of pairs: AWG24 × 4P	Cables	Tonichi Kyosan Cable, Ltd.		NETSTAR-C5E SAB 0.5 × 4P
			Kuramo Electric Co.		KETH-SB
			SWCC Showa Cable Systems Co.		FAE-5004
		RJ45 Connec- tors	Panduit Corporation		MPS588
	ber of pairs: AWG22 × 2P	Cables	Kuramo Electric Co., Ltd.		KETH-PSB- OMR
			Nihon Electric Wire&Cable Co.,Ltd		PNET/B
		RJ45 Assembly Connectors	OMRON Corporation		XS6G-T421-1

- *1. Cables are available in the following lengths: 0.2, 0.3, 0.5, 1, 1.5, 2, 3, 5, 7.5, 10, 15, and 20 m. Refer to the XS5/XS6 Industrial Ethernet Connectors Catalog (Cat. No. G019) for details.
- *2. Cable material LSZH. The lineup features Low Smoke Zero Halogen cables for in-cabinet use and PUR cables for out-of-cabinet use. Although the LSZH cable is single shielded, its communications and noise characteristics meet the standards. Cable colors available are blue, yellow and green.
- *3. For details contact your local OMRON representative.
- *4. We recommend to use the above cables and connectors together.



Additional Information

When making cables, connect the shield to the connectors at both ends.

2 Hardware

3

Software

This section provides software information for the IPC RTOS Controller.

3-1	Available Realtime Oper	rating Systems	3-2
0-1	Available Realtime Oper	ating bysterns	······································

3-1 Available Realtime Operating Systems

The available Realtime Operating Systems are:

- · Linux: Wind River Linux 7 (64bit) with EtherCAT Master
- VxWorks: Wind River VxWorks7 (64bit) with EtherCAT Master

Specifications

This section provides specifications of the IPC RTOS Controller.


4-1	Genera	I Specifications	4-2
	4-1-1	Dimensions and Weight	4-2
	4-1-2	General Electrical Specifications	4-3
	4-1-3	Power Consumption Specifications	4-4
	4-1-4	CPU Specifications	4-5
	4-1-5	Memory Specifications	
	4-1-6	Storage Device Specifications	4-6
	4-1-7	PCIe Card Specifications	
	4-1-8	Bracket Specifications	4-9
4-2	Connee	ctor Specifications	4-10
	4-2-1	Power Connector Specifications	4-10
	4-2-2	I/O Connector Specifications	
	4-2-3	USB Connector Specifications	4-15
	4-2-4	Ethernet Connector Specifications	4-15
	4-2-5	DVI Connector Specifications	4-18
	4-2-6	RS-232C Connector Specifications	4-19
4-3	Enviro	nmental Specifications	4-20
	4-3-1	Operation Environment Specifications	
	4-3-2	Temperature and Humidity Specifications	4-21
	4-3-3	Recycling Specifications	4-22

4-1 General Specifications

This section provides general specifications of the IPC RTOS Controller.

4-1-1 Dimensions and Weight

The following table provides specification details on dimensions and weights.



Item	Specifications	Specifications with book mount bracket	Specifications with wall mount brackets
Dimensions	Width X = 282 mm	Width X = 319 mm, this is the	Width X = 282 mm
	Depth Y = 195 mm	bracket height	Depth Y = 245 mm, this is the
	Y = 200 mm including the DVI	Depth Y = 207 mm	bracket length
	connectors	Height Z = 96 mm, this is the	Height Z = 92.2 mm
	Height Z = 88.75 mm	bracket width	
Weight	3.8 kg	4.9 kg	4.1 kg

4-1-2 General Electrical Specifications

The following table provides the general electrical specifications.

Item	Specifications
Rated power supply voltage	24 VDC
Allowable power supply voltage range	20.4 to 28.8 VDC
Power supply standard	SELV
Grounding method	Ground to less than 100 Ω
Inrush current	At 24 VDC: 12 A / 6 ms max. for cold start at room
	temperature
Overvoltage category	JIS B3502 and IEC 61131-2: Category II
EMC immunity level	IEC 61131-2: Zone B
RTC accuracy	At ambient temperature of 55°C: -3.5 to +0.5 min error
	per month
	At ambient temperature of 25°C: -1.5 to +1.5 min error
	per month
	At ambient temperature of 0°C: -3 to +1 min error per
	month
Power button life	100,000 operations
Fan life	8 years of continuous operation at 40°C
Battery life	5 years at 25°C (for battery CJ1W-BAT01)

4

4-1-3 **Power Consumption Specifications**

The following tables provide details on the power consumption of the IPC RTOS Controller. The total power consumption is the sum of the power consumption of all items that are installed in your Box PC.



Additional Information

Refer to 1-4 Product Configuration on page 1-5 for details.

Power Consumption with an Intel[®] Celeron[®] 2980U CPU

Power consumption specifications for IPC RTOS Controllers with an Intel[®] Celeron[®] 2980U CPU.

Item		Power consumption
Industrial Box PC with Intel [®] Celeron [®] 2980U exclud- ing Drives and Expansions		45 W
Drives *1	HDD 320 GB	2 W
	SSD SLC 32 GB	
	SSD SLC 64 GB	
	SSD iMLC 128 GB	
Expansions *2	USB	14 W max. ((2 x 500 mA at 5 V) + (2 x 900 mA at 5 V))
	PCle	5 W max.

*1. Refer to 1-4 Product Configuration on page 1-5 for product configuration details.

*2. Refer to the documentation of your expansions for their power consumption details.

The total power consumption is the sum of the power consumption of all items that are installed in your IPC RTOS Controller.

The required supply specifications for a Box PC with an Intel[®] Celeron[®] 2980U CPU.

Item	Minimum power requirements
Power supply	120 W
Refer to 2-9-8 Power Supply on page 2-20 for power	
supply products.	
UPS	120 W
Refer to 2-9-9 UPS on page 2-21 for UPS products.	

4-1-4 CPU Specifications

This section gives the specifications of the CPUs that are available for the IPC RTOS Controller. Refer to *1-4 Product Configuration* on page 1-5 for product configuration details.

Intel[®] Celeron[®] 2980U CPU Specifications

CPU specifications for IPC RTOS Controllers with an Intel[®] Celeron[®] 2980U CPU.

Item	Specifications	
Cores / Threads	2/2	
CPU base frequency	1.6 GHz	
Maximum turbo frequency		
Cache	2 MB	
Cooling details	Passive cooling (fanless)	
Drive bays (HDD/SSD)	1. Drive bay A.	
Graphics controller	Intel ® HD Graphics. Up to two independent screens.	

4-1-5 Memory Specifications

The following table provides specification details of the memory.

Item		Model Specifications		
		2 GB ^{*1}	4 GB ^{*1}	8 GB *1
Memory type		DDR3L		
Package memory format		SO-DIMM		
Serial Presence De- Speed grade		1600 Mbps		
tect (SPD)	CAS Latency	CL11		

*1. Refer to *1-4 Product Configuration* on page 1-5 for product configuration details.



Additional Information

The small outline dual in-line memory modules (SO-DIMM) cannot be added or replaced by users.

4

4-1-6 Storage Device Specifications

This section provides the specifications of the storage devices.

Hard Disk Drive Specifications

Specifications for the Hard Disk Drive (HDD) are provided in the table below.

llene	Model Specifications		
Item	320 GB ^{*1}		
Model	NY000-AH00		
S.M.A.R.T. support	Yes		
Rotation speed	5,400 r/min		
Interface	Serial ATA 3.0		
Operating temperature	5 to 55°C *2		
Operating humidity	10% to 95% (with no condensation)		
	29°C wet-bulb temperature max.		
Storage temperature	-40 to 65°C		
Storage humidity	8% to 90% (with no condensation)		
	40°C wet-bulb temperature max.		
Life	Approximately 5 years or 20,000 powered-ON hours		
	(whichever comes first) under the following conditions:		
	• 25°C at 101.3 kPa		
	 Less than 333 powered-ON hours/month^{*3} 		
	 Less than 20% operation while powered-ON^{*4} 		
	Less than 1.30 x 10 ⁶ seeks/month		

*1. Refer to 1-4 Product Configuration on page 1-5 for product configuration details.

*2. Refer to 4-3-1 Operation Environment Specifications on page 4-20 for the temperature specifications of the complete Box PC

*3. Powered-ON hours include sleep and standby modes.

*4. Operation includes seeking, writing, and reading functions.

Solid State Drive Specifications

Specifications for the Solid State Drive (SSD) are provided in the table below.

lite and	Model Specifications			
Item	32 GB ^{*1}	64 GB ^{*1}	128 GB ^{*1}	
Model	NY000-AS00	NY000-AS01	NY000-AS02	
Туре	SLC	SLC	iMLC	
S.M.A.R.T. support	Yes			
Interface	Serial ATA 3.1			
Sustained read speed	Up to 160 MB/s		Up to 430 MB/s	
Sustained write speed	Up to 150 MB/s		Up to 190 MB/s	
Operating temperature	0 to 70°C *2			
Operating humidity	10% to 95% (with no conde	ensation)		
Storage temperature	-40 to 100°C			
Storage humidity	10% to 95% (with no condensation)			

	Model Specifications			
Item	32 GB ^{*1}	64 GB ^{*1}	128 GB ^{*1}	
Life	1500 TB/11 years at a daily workload of 350 GB	3000 TB/23 years at a daily workload of 350 GB	114 TB/3 years at a daily workload of 100 GB	

*1. Refer to 1-4 Product Configuration on page 1-5 for product configuration details.


*2. Refer to 4-3-1 Operation Environment Specifications on page 4-20 for the temperature specifications of the complete Box PC

4

4-1-7 PCIe Card Specifications

The PCI Express (PCIe) Card slot of the IPC RTOS Controller accepts various cards for specific hardware needs.

Ensure that, according to the PCIe hardware specifications, the indent A is present in the PCIe Card.



The following tables provide PCIe Card details per CPU type.

PCIe Card Slot Specifications with an Intel[®] Celeron[®] 2980U CPU

The table below provides PCIe Card slot details for IPC RTOS Controllers with an Intel[®] Celeron[®] 2980U CPU.


Item	Specifications		
Configuration	X1 (1 lane) up to Gen 2		
Card height	Standard height cards, 4.20 inches (106.7 mm) ^{*1}		
Card length	Half-length cards, 6.6 inches (167.65 mm)		
Power consumption	Refer to <i>Power Consumption with an Intel[®] Celeron[®] 2980U CPU</i> on page 4-4 for the maximum power consumption		

*1. Low profile cards, 2.536 inches (64.4 mm) are not supported.

4-1-8 Bracket Specifications

The metal mounting brackets mount your Box PC and they are the connection for the functional ground.

Use metal screws with a diameter of 4 mm or 5 mm to mount the brackets. Mounting screw locations for book mount and wall mount orientation:



- Refer to 5-3-8 Book Mount Procedure on page 5-26 for book mount details.
- Refer to 5-3-9 Wall Mount Procedure on page 5-27 for wall mount details.

4

4-2 Connector Specifications


This section provides the Connector Specifications of the IPC RTOS Controller.

4-2-1 Power Connector Specifications

The power supply connector can be locked to prevent unintentional disconnection.

The connector can only be inserted the correct way. The connector is a Phoenix Contact type SPC5/2-STCL-7.62 BK (1711708).

The Box PC provides protection against reverse polarity.



The pin layout represents the power connector on the Box PC.

Pin	Description
1	24 VDC
2	0 VDC

Item	Specifications
Conductor isolation rating	90°C
Termination rating	90°C




Additional Information

- Refer to 5-4-3 Wire the Power Connector on page 5-36 for wiring details.
- Refer to 5-4-2 Ground on page 5-29 for grounding details.

Locking and Removing the Power Connector

The power connector automatically locks into place when the black part of the connector is held and pushed in.



Pushing both orange sliders $^{(B)}$ towards the end of the connector $^{(A)}$ will release the lock when removing the connector.


4-2-2 I/O Connector Specifications

Details of the I/O connector are provided below.

The I/O connector can be locked to prevent unintentional disconnection.

The connector can only be inserted in the correct way.


The Lock-and-Release Latch connector is a Phoenix Contact type DFMC 1,5/ 3-ST-3,5-LR BK (1711658).



Item	Specifications
Conductor isolation rating	90°C
Termination rating	90°C

I/O Connector Pin Details

The pin details of the I/O connector.



The pin layout represents the I/O connector on the Box PC.

The I/O signals connected must be powered from a power supply which conforms to the SELV standards.

Pin	Descrip- tion	Туре	Electrical Specifications	Details
1 2	Power Sta- tus Output *1	Contact out- put	 SPST-NO contact configuration 24 VDC at 2A switch- ing capacity (resistive load) Operation lifetime 150,000 cycles at 2A max. Connect to SELV 	 Open: The Power Status Output is OFF when the Box PC is OFF or has been dis- connected from the power supply. Closed: The Power Status Output is ON when the Box PC has shutdown success- fully and is connected to the power supply and has not been disconnected from that power supply since power OFF. Refer to I/O Connector Power Status Output Details on page 4-13 for details.
3 4	Power ON/OFF In- put ^{*2}	Isolated tran- sistor input (sinking or sourcing)	 ON: 8.8 VDC min./5 mA min. OFF: 1.1 VDC max./0.5 mA max. Connect to SELV 	 If the signal changes from inactive to active, the Box PC will perform one of the following operations. When powered ON, the Box PC will shut down and power OFF. When powered OFF, the Box PC will power ON.
5 6	UPS Mode Input			This input is provided to allow monitoring the state of an external UPS unit that provides a compatible power state output signal.

*1. Refer to *I/O Connector Power Status Output Details* on page 4-13 for Power Status Output details.

*2. Refer to 6-1 Power ON on page 6-2 and 6-2 Power OFF on page 6-3 for Power ON/OFF Input details.

Additional Information

Refer to 5-4-4 Wire the I/O Connector on page 5-39 for I/O connector wiring details.

I/O Connector Power Status Output Details

This section provides details of the Power Status Output relay.

The Power Status Output is a relay between pin 1 and 2 of the I/O Connector.

Power ON Power Status Output Operation


This section provides power ON details of the Power Status Output operation.

The Power Status Output turns ON to indicate that the system has been shut down and the power supply to the Box PC can be turned OFF.

If power is not turned OFF, the Power Status output will turn OFF when the Box PC is turned ON.

The Power Status Output is ON A when the Box PC has been used and has not been disconnected from the power supply.

The Power Status Output is OFF (B) when the Box PC has been disconnected from the power supply.



Additional Information

Refer to 5-4-4 Wire the I/O Connector on page 5-39 for I/O connector wiring details.

Power OFF Power Status Output Operation


This section provides power OFF details of the Power Status Output operation.

The Power Status Output turns ON to indicate that the system has been shut down and the power supply to the Box PC can be turned OFF.

If power is not turned OFF, the Power Status output will stay ON $^{(A)}$. It will turn OFF when the Box PC is turned ON.


If power is turned OFF, the Power Status Output will turn OFF $^{(B)}$.

4



Lock and Remove the I/O Connector


The I/O connector locks into place when the black part of the connector is held and pushed in.



Tilting both levers B will release the I/O connector A from the Box PC.

4-2-3 USB Connector Specifications

The IPC RTOS Controller includes four USB connectors. Two connectors provide version 2.0 performance and two connectors provide version 3.0 performance. Details of the USB interface connectors are provided below.



The connector layout represents the USB connectors on the Box PC.

Details
• USB 3.0
900 mA maximum current
3 m maximum cable length
Blue color
• USB 2.0
500 mA maximum current
5 m maximum cable length
Black color




Additional Information

Refer to 5-4-2 Ground on page 5-29 for grounding details.

4-2-4 Ethernet Connector Specifications


Details of the RJ45 Ethernet connectors are provided below. The Ethernet connector locks automatically to prevent unintentional disconnection. 4



The view represents the Ethernet connector on the IPC RTOS Controller.

Ethernet Connector LED Indicators

Each connector has LED indicators for speed, link and activity.



Item	Indicator	Color	Status		Description
A	Link/Act	Yellow		Not lit	No link
				Lit	Link
				Flashing	Link and activity
В	Speed	Not lit		Not lit	10 Mbps or no link
		Green		Lit	100 Mbps link
		Orange		Lit	1 Gbps link


Ethernet Connector Specifications

Item	Specifications
Number of available ports	3
Physical layer	10BASE-T, 100BASE-TX or 1000BASE-T
Frame length	1,514 bytes max.
Media access method	CSMA/CD
Modulation	Baseband
Тороlоду	Star
Transmission media	STP (shielded, twisted pair) cable of Ethernet category 5,5e or higher
Maximum transmission distance between Ethernet switch and node	100 m
Maximum number of cascade connections	There are no restrictions if an Ethernet switch is used

4-2-5 DVI Connector Specifications

DVI is the standard video interface for the Box PC.

The video interface depends on the model of the Box PC as specified below:





Additional Information

- Refer to 4-1-4 CPU Specifications on page 4-5 for graphics controller details.
- Refer to 5-4-2 Ground on page 5-29 for grounding details.
- Refer to A-2 DVI-D Connector Pin Details on page A-12 for pin details.

The following tables provide DVI details per CPU type.


DVI-D Connector Specifications with an Intel[®] Celeron[®] 2980U CPU

DVI-D connector specifications for IPC RTOS Controller with an Intel[®] Celeron[®] 2980U CPU.

Item Specifications		
Video interface	Digital only	
Resolution	Up to 1920 x 1200 pixels at 60 Hz	
Туре	Dual link	
Maximum DVI cable length Dependent upon connected monitor type and resolution		

4-2-6 RS-232C Connector Specifications

The optional RS-232C interface on the Box PC uses a standard SUBD9 connector. The RS-232C interface is not isolated from the internal Box PC's components.





Additional Information

- Refer to 5-4-2 Ground on page 5-29 for grounding details.
- Refer to A-3 RS-232C Connector Pin Details on page A-13 for pin details.

4-3 Environmental Specifications

This section provides environmental specifications of the IPC RTOS Controller.

4-3-1 **Operation Environment Specifications**

The following table provides the general environmental specifications for the Industrial Box PC.

Item	Specifications		
Ambient operating temperature	0 to 55°C ^{*1}		
Ambient storage temperature	-20 to 70°C *1		
Ambient operating humidity	10% to 90% with no condensation		
Ambient storage humidity	10% to 90% with no condensation		
Operating atmosphere	No corrosive gases		
Altitude	2,000 m max.		
Noise resistance (during operation) Conforms to IEC61000-4-4, 2kV (power lines)			
Vibration resistance (during opera-	Conforms to IEC 60068-2-6.		
tion)	For a Box PC with an SSD: 5 to 8.4 Hz with 3.5 mm single amplitude and 8.4 to 150 Hz with 9.8 m/s ² for 10 times each in X, Y and Z directions.		
	For a Box PC with a HDD the vibration resistance depends on the mount-		
	ing orientation ^{$*2$} .		
Shock resistance (during operation)	Conforms to IEC 60068-2-27.		
	147 m/s ² , 3 times in each X, Y and Z directions		
Pollution degree JIS B3502 and IEC 61131-2: 2 or less			
RTC accuracy	At ambient temperature of 55°C: −3.5 to +0.5 min error per month		
	At ambient temperature of 25°C: −1.5 to +1.5 min error per month		
	At ambient temperature of 0°C: -3 to +1 min error per month		

*1. Refer to 4-3-2 *Temperature and Humidity Specifications* on page 4-21 for ambient operating temperature details per CPU type.

*2. Vibration resistance depends on the Box PC's mounting orientation and storage device type:

Mounting Orientation	SSD	HDD
Book	9.8 m/s²	2.5 m/s²
Wall		4.9 m/s ²

4-3-2 Temperature and Humidity Specifications

The allowed ambient operating temperature and ambient humidity depend on product type, CPU type, mounting orientation, and storage device type.


The following sections provide temperature and humidity details per CPU type.

Temperature and Humidity Graphs

The maximum ambient operating temperature and ambient humidity are specified per CPU type, mounting orientation and storage device type.

The following graphs provide ambient temperature and humidity details per storage device type and the conditions for storage.


- Operate the Box PC with a SSD within the general environmental specifications.
- Operate the Box PC with a HDD within the ambient temperature and humidity ranges as shown in following graph.



Additional Information

Refer to the ambient temperature and humidity specifications per CPU type for specific limitations.

- Store the Box PC with a SSD within the general environmental specifications.
- Store the Box PC with a HDD within the ambient temperature and humidity ranges as shown in following graph.



Temperature Specifications with an Intel[®] Celeron[®] 2980U CPU

Ambient operating temperature specifications for a Box PC with an Intel[®] Celeron[®] 2980U CPU.

Mounting Orientation	Storage device type *1	
	SSD	HDD
Book	0 to 55°C	5 to 45°C
Wall	0 to 50°C	5 to 40°C

*1. Refer to 1-4 Product Configuration on page 1-5 for model details.

Additional Information

Refer to *Temperature and Humidity Graphs* on page 4-21 for graph details.

4-3-3 Recycling Specifications

The following table provides recycling information for the IPC RTOS Controller.

Part	Recycle specifications
Battery	Chemical waste
PCIe Card and other electrical components	Electrical waste

Precautions for Safe Use

Dispose of the product and batteries according to local ordinances as they apply.



5

Installation

This section provides all installation details for the IPC RTOS Controller.

5-1	Unpac	:k	
	5-1-1	Unpack Procedure	
	5-1-2	Items Supplied	
5-2	Install		
J- 2		Options	
	5-2-1 5-2-2	Install a Drive	
	5-2-2	Install the PCIe Card	
5-3	Mount		5-14
	5-3-1	Installation Method in Control Panels	5-14
	5-3-2	Product Orientation	
	5-3-3	Temperature	
	5-3-4	Humidity	5-18
	5-3-5	Vibration and Shock	
	5-3-6	Atmosphere	5-19
	5-3-7	Electrical Environment	
	5-3-8	Book Mount Procedure	
	5-3-9	Wall Mount Procedure	
5-4	Wire		5-28
• •	5-4-1	Wiring Warnings and Cautions	
	5-4-2	Ground	
	5-4-3	Wire the Power Connector	
	5-4-4	Wire the I/O Connector	
5-5	Conne	ect	5-42
0-0	5-5-1	Connector Identification	
	5-5-2	Connection Procedure	
5-6		Power ON	
	5-6-1	Initial Power ON Procedure	5-46
5-7	Conne	ect UPS	5-48
	5-7-1	Connect UPS Using the USB Connector	

5-1 Unpack

This section provides details on how to unpack the IPC RTOS Controller.

5-1-1 Unpack Procedure

- **1** Check the package for damage. If there is any visible damage:
 - Take photos of the package and save them.
 - Inform your supplier immediately.
- **2** Open the package. Ensure not to damage the contents.
- **3** En

Ensure that all items are present.

Additional Information

Refer to 5-1-2 Items Supplied on page 5-2 for the items supplied.

5-1-2 Items Supplied

The Industrial Box PC is supplied with several items.




Additional Information


- Refer to Items Supplied with the Industrial Box PC on page 5-3 for more details.
- · Refer to Items Supplied with the Brackets on page 5-4 for more details.

Items Supplied with the Industrial Box PC

This section describes the items supplied with your Industrial Box PC.

- Industrial Box PC
- Documentation:
 - Safety Precautions sheets (English and Japanese)
 - EU Compliance sheet
 - · Standards and Certifications sheet
- Bag with:
 - Power connector
 - I/O connector
 - Drive bracket for drive installation
 - 4 Mounting screws for drive installation
 - PCIe Card support for PCIe Card installation





Items Supplied with the Brackets

This section describes the items supplied with the brackets for your Industrial Box PC.



Additional Information

- Refer to 2-9-1 Mounting Brackets on page 2-17 for bracket details.
- Refer to 5-3-8 Book Mount Procedure on page 5-26 for book mount installation.
- Refer to 5-3-9 Wall Mount Procedure on page 5-27 for wall mount installation.

Book Mount

Check if the content is complete.

Supplied items:

- 1 Book mount bracket
- 6 Mounting screws
- 1 Nut for the functional ground terminal connection
- 2 Washers for the functional ground terminal connection

Wall Mount

Check if the content is complete.

Supplied items:

- 2 Wall mount brackets
- 6 Mounting screws
- 1 Nut for the functional ground terminal connection
- 2 Washers for the functional ground terminal connection

5-2 Install Options

This section describes the installable options for the IPC RTOS Controller.

5-2-1 Install a Drive

A drive is a storage device for the IPC RTOS Controller.



Additional Information

- Depending on the product configuration a drive is already installed. Refer to *1-4 Product Configuration* on page 1-5 for storage details.
- Depending on the CPU type one or two drives are supported.
- Refer to 4-1-4 CPU Specifications on page 4-5 for the number of supported drives.
- Refer to 2-9-4 Storage Devices on page 2-18 for the recommended drive models.
- Refer to 4-1-6 Storage Device Specifications on page 4-6 for drive specifications.

Prepare the following items:


The drive

A drive is not supplied with the Box PC.

• The drive bracket with mounting screws These are supplied with the Box PC.

To install a drive:

- 1 Ensure the Box PC is OFF.
- **2** Remove the drive cover.




- 1) Push the lock lever $\mathbf{0}$.
- 2) Tilt the drive cover $\mathbf{2}$.
- 3) Remove the drive cover \Im .

3


Pull the metal shielding cover out of the Box PC.

4 Align the connectors of the drive as shown A on the bracket. Then insert the replacement drive in the bracket and insert the 4 mounting screws 2. Tighten these screws with a torque of 0.35 N⋅m.




- **5** Insert the bracket with the drive in the correct bay.
 - · A drive for the operating system has to be inserted in bay A
 - The drive for additional storage can be inserted in bay B

Ensure the bracket is completely in the Box PC with an extra push.



The drive bracket will lock into place when it is fully inserted.

6 Insert the metal shielding cover.







- If the drive is inserted in bay A:
 - 1) Install an operating system
 - 2) Power OFF and then Power ON
 - 3) Ensure the drive is functional and confirm normal operation.
 If required set the drive as boot disk in the BIOS settings.
 Refer to A-1-5 BIOS Boot on page A-10 for boot priority settings.
- If the drive is inserted in bay B:
 - 1) Ensure the drive is functional and confirm normal operation.
 - If the Box PC has a Windows operating system and the storage drive is not visible in Windows then the drive needs to be allocated.

The drive is installed and functional.

5-2-2 Install the PCIe Card

Prepare the following items:

• The PCIe Card.

A PCIe Card is not supplied with the Box PC.

Additional Information


Refer to 4-1-7 PCIe Card Specifications on page 4-8 for PCIe specifications.

• The PCIe Card mounting material: Card Support. This item is supplied with the Box PC.


To install the PCIe Card:


- 1 Ensure the Box PC is OFF.
- **2** Remove the two crosshead screws **1** indicated with "open" and then pull up **2** the PCIe Drawer.


The indent at the side of the drawer will help you to pull the drawer from the Box PC.



3 Pull the middle of the Card Clip to unlock it and remove it from the PCIe Drawer.









The slot cover is now removed.

5 Place the PCle Card in the PCle Drawer.



Ensure to insert the PCIe Card in the correct opening. Ensure the thin sheet metal frame is positioned between the PCIe Card and the PCIe Drawer to ensure a good conductive contact.


6 Place the Card Clip in the PCIe Card and PCIe Drawer 1 and then rotate the Clip 2 to lock it in place.




5


7 Slide the Card Support ① so that it supports the side of the PCIe Card.The card should be in small groove so there is support below and above the card.

Rotate the Card Support **2** to lock it in place.



8 Insert the PCIe Drawer in the Box PC and then insert the two crosshead screws that hold the PCIe Drawer in place.





- 1) Push the lock lever \bullet .
- 2) Tilt the PCIe cover **2**.
- 3) Remove the PCIe cover **3**.

The PCIe Card is installed.

5-3 Mount

This section describes how to mount the Box PC in either a book or wall orientation inside a control panel.

🗥 WARNING

Ensure that installation and post-installation checks of the product are performed by personnel in charge who possess a thorough understanding of the machinery to be installed.

5-3-1 Installation Method in Control Panels

The IPC RTOS Controller must be mounted in a cabinet or a control panel.

Consider the orientation, cooling distance, noise resistance, ducts and Box PC replacement when determining the space between the Box PC and other devices.



Precautions for Safe Use

Install the product in the correct orientation and temperature according to the specifications in the manual to prevent overheating. Not doing so may result in malfunction.



Precautions for Correct Use

Do not operate or store the product in the following locations. Operation may stop or malfunctions may occur.

- · Locations subject to direct sunlight
- Locations subject to temperatures or humidity outside the range specified in the specifications
- · Locations subject to condensation as the result of severe changes in temperature
- Locations subject to corrosive or flammable gases
- · Locations subject to dust (especially iron dust) or salts
- · Locations subject to exposure to water, oil or chemicals
- · Locations subject to shock or vibration



Additional Information


- Ensure you have installed the options before you mount the product. Refer to *5-2 Install Options* on page 5-5 for option details.
- Refer to 5-3-8 Book Mount Procedure on page 5-26 or 5-3-9 Wall Mount Procedure on page 5-27 for orientation details.
- Refer to 5-3-3 Temperature on page 5-15 for temperature details.
- Refer to 5-3-4 Humidity on page 5-18 for humidity details.
- Refer to 5-4 Wire on page 5-28 for wiring details.

5-3-2 **Product Orientation**

The Box PC can be mounted in a book A or wall B C orientation.


- For book mount there is one allowed orientation (A).
- For wall mount there are two allowed orientations, horizontally mounted (B) and vertically mounted (\mathbf{C})

Do not install the Box PC in other orientations.




Book mount Frontview Sideview





Wall mount Frontview Frontview



Sideview

5-3-3 Temperature

The temperature inside a control panel may be at least 10 to 15°C higher than outside the panel. Implement the following measures against overheating at the installation site and in the control panel, and allow a sufficient margin for the temperature.

Distance for Cooling

Adequate airflow around the Industrial Box PC is required.




Additional Information


- The ambient temperature must be within the operating range. Refer to 4-3-1 Operation Environment Specifications on page 4-20 for temperature specifications.
- Allow space to accommodate for the bending radius of the cables. Refer to:
 - 2-9-5 DVI Cables on page 2-19
 - 2-9-6 USB Type-A to USB Type-B Cables on page 2-19
 - for cable bending requirements.

Provide enough space for good air flow and ensure the following minimum distances are observed around the sides of the Box PC.

Book Mount



- Wall Mount in landscape A or portrait B orientation



Item	Minimum distance ^{*1}
Х	50 mm
Y	100 mm
Z	50 mm

*1. Measure the minimum distances X and Y at the air openings in the sides of the Box PC.


High Temperatures

Use the following cooling methods as required, taking into account the ambient temperature and the amount of heating inside the panel.

Natural Cooling

Natural cooling relies on natural ventilation through slits in the panel, rather than using cooling devices such as fans or coolers. When using this method, observe the following points.


- Do not install the Box PC at the top of the panel, where hot air tends to stagnate.
- To provide ventilation space above and below the Box PC, leave sufficient distance from other devices, wiring ducts, etc.
- Do not mount the Box PC in the wrong direction (e.g., vertically or upside down). Doing so may cause abnormal heating in the Box PC.
- Do not install the Box PC directly above any heat-generating equipment, such as heaters or transformers.
- Do not install the Box PC in a location exposed to direct sunlight.



Natural Cooling

Forced Ventilation


Forced ventilation with a fan in the top of the control cabinet.



Forced Ventilation Method

• Forced Air Circulation


Forced circulation with a fan inside the closed control cabinet.



Forced Air Circulation

Room Cooling

Cool the entire room where the control panel is located.



Room Cooling

Low Temperatures


The Box PC may not start normally if the temperature is below 0°C when the power is turned ON. Maintain an air temperature of at least 5°C inside the panel, by implementing measures such as installing a low-capacity space heater in the panel.

Alternatively, leave the Box PC power ON to keep the Box PC warm.

5-3-4 Humidity

Rapid temperature changes can cause condensation to occur, resulting in malfunctioning due to shortcircuiting.

When there is a possibility of this occurring, take measures against condensation, such as leaving the Box PC power ON at night or installing a heater in the control panel to keep it warmer.



Examples of Measures against Condensation

5-3-5 Vibration and Shock

The Box PC is tested for conformity with the sine wave vibration test method (IEC 60068-2-6) and the shock test method (IEC 60068-2-27) of the Environmental Testing for Electrotechnical Products. It is designed so that malfunctioning will not occur within the specifications for vibration and shock. If, however, the Box PC is to be used in a location in which it will be directly subjected to regular vibration or shock, then implement the following countermeasures:

- Separate the Box PC control panel from the source of the vibration or shock. Or secure the Box PC and the control panel with rubber padding to prevent vibration.
- · Make the building or the floor vibration-resistant.
- Prevent shocks when other devices in the panel, such as electromagnetic contactors, operate. Secure either the source of the shock or the Box PC with rubber padding.

5-3-6 Atmosphere

Using the Box PC in any of the following locations can cause defective contact with connectors and corrosion of components. Implement countermeasures such as purging the air as required.


- In locations exposed to dust, dirt, salt, metal powder, soot, or organic solvents, use a panel with an airtight structure. Be careful of temperature increases inside the panel.
- In locations exposed to corrosive gas, purge the air inside the panel to clear the gas and then pressurize the inside of the panel to prevent gas from entering from outside.
- In locations where flammable gas is present, either use an explosion-protected construction or do not use the Box PC.

5-3-7 Electrical Environment

When installing or wiring devices, make sure that there will be no danger to people and that noise will not interfere with electrical signals.

Installation Location


Install the Box PC as far away as possible from high-voltage (600 V or higher) and power devices to ensure safe operation and maintenance.



Examples of Equipment Arrangement in Panel with High-voltage Devices

Hardware Arrangement

The coils and contacts in electromagnetic contacts and relays in an external circuit are sources of noise. Do not install them close to the Box PC. Locate them at least 100 mm away from the Box PC.




Example of Arrangement in Panel

Wire Layout for the Power Supply

Observe the following points when wiring the power supply system.


- Separate the Box PC power supply from the I/O device power supply and install a noise filter near the Box PC power supply feed section.
- Use an isolating transformer to significantly reduce noise between the Box PC and the ground. Install the isolating transformer between the Box PC power supply and the noise filter, and do not ground the secondary coil of the transformer.
- Keep the wiring between the transformer and the Box PC as short as possible, twist the wires well, and keep the wiring separate from high-voltage and power lines.



Wire External I/O Signal Lines

Observe the following points when wiring the external I/O signal lines.

 To absorb reverse electromotive force when an inductive load is connected to an output signal, connect a surge suppressor near the inductive load in an AC circuit, or connect a diode near the inductive load in a DC circuit.




Input Signal Noise Countermeasures

Output Signal Noise Countermeasures

▼ Diode

• Never bundle output signal lines with high-voltage or power lines, and do not route them in close proximity or parallel to such lines.

If output signal lines must be routed in close proximity to such lines, place them in separate ducts or conduits. Be sure to ground the ducts or conduits.



I/O Cable Arrangement

- If the signal lines and power lines cannot be routed in separate ducts, use shielded cable. Connect the shield to the ground terminal at the Box PC, and leave it unconnected at the input device.
- Wire the lines so that common impedance does not occur. Such wiring will increase the number of wires, so use common return circuits. Use thick wires with sufficient allowance for the return circuits, and bundle them with lines of the same signal level.
- For long I/O lines, wire the input and output signal lines separately.
- Use twisted-pair wires for pilot lamps (and particularly lamps with filaments).
- Use countermeasures, such as CR surge absorbers and diodes, for input device and output load device noise sources, as required.

External Wiring

Wiring, and noise countermeasures in particular, are based on experience, and it is necessary to closely manage wiring based on experience and information in the manuals.

• Wiring Routes


Each of the following combinations includes different signal types, properties, or levels. They will cause the signal-to-noise ratio to drop due to factors such as electrical induction. As a general rule when wiring, either use separate cables or separate wiring routes for these items. Future maintenance operations and changes to the system will also be made easier by carefully organizing the wiring from the start.

- Power lines and signal lines
- · Input signals and output signals
- · Analog signals and digital signals
- · High-level signals and low-level signals
- · Communications lines and power lines
- DC signals and AC signals
- · High-frequency devices (such as Inverters) and signal lines (communications)

• (Routing of) Wiring


Observe the following points when wiring power supply and signal cables.

- When routing signal cables with differing characteristics through the same duct, always keep them separated.
- As much as possible, avoid routing multiple power supply lines through the same duct. If it cannot be avoided, then construct a partition between them in the duct and ground the partition.




Partitioning Methods for Signal and Power Supply Cables

• To avoid overheating the conduits when using conduits for wiring, do not place wires for a single circuit in separate conduits.



- Power cables and signal cables adversely affect each other. Do not wire them in parallel.
- Noise induction may occur if the Box PC is installed in a panel that includes high-voltage devices. Wire and install them as far apart as possible.
- Either install the Box PC a minimum of 200 mm away from high-voltage lines or power lines, or place the high-voltage lines or power lines in metal tubing and completely ground the metal tubing to 100 Ω or less.



Example: Separating an OMRON product from Power Lines

• Wiring Ducts

Whenever possible, route the cables and wires through wiring ducts. Install the wiring ducts so that it is easy to route the wires from the IPC RTOS Controller directly into the duct.



Additional Information

Refer to Distance for Cooling on page 5-15 for the minimum required distances.

It is convenient to use wiring ducts that have the same depth as the IPC RTOS Controller.



5-3-8 Book Mount Procedure


Use the following procedure to mount the IPC RTOS Controller in the book orientation.

Additional Information

- Refer to 5-4-2 Ground on page 5-29 for grounding details.
- Refer to 2-9-1 Mounting Brackets on page 2-17 for the bracket model.

To mount the Box PC:

1 Mount the Bracket B to the Industrial Box PC C with the 6 Phillips screws B supplied with the brackets. Tighten these screws with a torque of 0.5 N·m.



- **2** Mount the Box PC with the bracket in position.
 - Drill the four holes at the location where the Box PC with bracket will be mounted. Refer to *4-1-8 Bracket Specifications* on page 4-9 for details.
 - Position the Industrial Box PC with bracket in the mounting location.

- Insert screws through the bracket into the mounting surface. Note that these screws are not in the scope of delivery.
- Tighten all four screws with a torque of 0.5 N·m.

The Box PC is mounted.

5-3-9 Wall Mount Procedure

Use the following procedure to mount the Box PC in the wall orientation.




Additional Information

- Refer to 5-4-2 Ground on page 5-29 for grounding details.
- Refer to 2-9-1 Mounting Brackets on page 2-17 for the bracket model.

To mount the Box PC:

1 Mount the Brackets B to the Industrial Box PC C with the 6 Phillips screws B supplied with the brackets.

Tighten these screws with a torque of 0.5 $N\!\cdot\!m.$



- 2 Mount the Industrial Box PC with the brackets in position.
 - Drill the four holes at the location where the Box PC with brackets will be mounted. Refer to *4-1-8 Bracket Specifications* on page 4-9 for details.
 - Position the Industrial Box PC with bracket in the mounting location.
 - Insert screws through the bracket into the mounting surface. Note that these screws are not in the scope of delivery.
 - Tighten all four screws with a torque of 0.5 $N{\cdot}m.$

The Box PC is mounted.

5-4 Wire

This section describes how to wire the IPC RTOS Controller.



This section describes the Warnings and Cautions when wiring the IPC RTOS Controller.

Provide safety measures in external circuits to ensure safety in the system if an abnormality occurs due to malfunction of the product or due to other external factors affecting operation. Not doing so may result in serious accidents due to incorrect operation.



🗥 WARNING

Emergency stop circuits, interlock circuit, limit circuits, and similar safety measures must be provided in external control circuits.

🗥 WARNING

Unintended behavior may occur when an error occurs in internal memory of the product. As a countermeasure for such problems, external safety measures must be provided to ensure safe operation of the system.





Precautions for Safe Use

Do not let metal particles enter the product when preparing the panel. Do not allow wire clippings, shavings, or other foreign material to enter any product. Otherwise, the product burning, failure, or malfunction may occur. Cover the product or take other suitable countermeasures, especially during wiring work.

5-4-2 Ground

This section describes how to ground the IPC RTOS Controller.




Always connect to a ground of 100 $\boldsymbol{\Omega}$ or less when installing the product.

0

Caution

The product has an internal non-isolated DC power supply. Circuit ground (0 VDC) and frame ground are connected together. When connecting a non-isolated device or a non-isolated interface to the product, take appropriate actions to avoid communication failures or damage to the mentioned ports.



▲ Caution

Never ground the 24 VDC side of the power supply. This may cause a short circuit.

The shielding of the communication connectors are directly bonded to the case and to the functional ground of the Box PC.

The shield of a communication cable should be terminated to ground at both ends of the cable with a low impedance connection. A large surface area surrounding the entire cable shield ensures a low impedance connection, avoid the use of pigtails.

Potential differences between the two connected communicating devices might cause an equipotential current to flow through the shielding connected at both ends.

To avoid equipotential currents on the cable shields, an additional equipotential bonding conductor must be installed.

Refer to IEC 61918 for guidelines regarding conductor sizing and length to prevent a voltage offset between two communicating devices exceeding 1 V.

Make sure to run the bonding conductor in close proximity to the communication cable.

5-4 Wire

Considerations for Earthing Methods

Local potential fluctuations due to lightning or noise occurred by power devices will cause potential fluctuations between ground terminals of devices. This potential fluctuation may result in device malfunction or damage. To prevent this, it is necessary to suppress the occurrence of a difference in electrical potential between ground terminals of devices. You need to consider the earthing methods to achieve this objective.

The recommended earthing methods for each usage condition are given in the following table.

Specification of commu-		Earthing methods	
nications cables	Equipotential bonding system	Star earthing	Daisy chain
The cable shield connect- ed to the connector hood at both ends of the com- munications cable	Recommended	Not recommended	Not recommended



Additional Information

- In a country or region where the earthing method is regulated, you must comply with the regulations. Refer to the applicable local and national ordinances of the place where you install the system, or other international laws and regulations.
- Ethernet switches are used with the EtherNet/IP. For information on the environmental resistance of the Ethernet switch to use, the grounding between Ethernet switches, or the specifications of cables, ask the Ethernet switch manufacturer.

Each of these earthing methods is given below.


Equipotential Bonding System

Equipotential bonding is an earthing method in which steel frames and building structures, metal ducts and pipes, and metal structures in floors are connected together and make connections to the earth trunk line to achieve a uniform potential everywhere across the entire building. We recommend this earthing method.

The following figure shows an example of an equipotential bonding system.

Connect the main earthing terminal and building structures together with equipotential bonding conductors and embed the mesh ground line in each floor.

Connect the ground line of each control panel to the equipotential bonding system.



5-4-2 Ground

Star Earthing


If the earthing method used for the building is not equipotential bonding or the earthing system is unknown, choose (a) from among the earthing methods given below.

a. Connecting devices and noise sources to separate earth electrodes


This is an earthing method to separately ground an earth electrode of the device that is connected with a communications cable or other devices and an earth electrode of a high-power device that could be a noise source, such as a motor or inverter.

Each earth electrode must be ground to 100 Ω or less.

Connect the ground lines of the device that is connected with a communications cable and other devices as a bundle to a single earth electrode. Be sure that the earth electrode is separated by a minimum of 10 m from any other earth electrode of a device that could be a noise source.




b. Connecting devices and noise sources to a common earth electrode
 This is an earthing method to connect the device that is connected with a communications cable, other devices, and a device that could be a noise source, to a common earth electrode.
 This earthing method is not recommended because the device that could be a noise source may interfere electromagnetically with other devices.



Daisy Chain

This is an earthing method to connect the device that is connected with a communications cable, other devices, and a device that could be a noise source using a daisy-chain topology to a common earth electrode.

This earthing method is not recommended because the device that could be a noise source may interfere electromagnetically with other devices.




Ground Connection Details

This section provides details about the ground connection.

Use the functional ground terminal on the mounting bracket(s) to ground your Industrial Box PC.

The washers and nut \bigcirc are supplied with the bracket(s). Refer to *Items Supplied with the Brackets* on page 5-4 for details.


Book Mount



Mount the ground connection wire $^{\textcircled{B}}$ to the functional ground terminal $^{\textcircled{A}}$ using the washers and nut $^{\textcircled{C}}$. Tighten the nut with a torque of 1.2 N·m max.

Refer to 5-3-8 Book Mount Procedure on page 5-26 for book mounting details.

Wall Mount




Mount the ground connection wire B to the functional ground terminal A using the washers and nut C. Tighten the nut with a torque of 1.2 N·m max.

Refer to 5-3-9 Wall Mount Procedure on page 5-27 for wall mounting details.

• Crimp terminals

Use crimp terminals with dimensions X = M4 and Y = 8 mm max.





5-4-3 Wire the Power Connector

This section describes how to wire the power connector.



Precautions for Safe Use

- Do not perform a dielectric strength test.
- Always use the recommended uninterruptible power supply (UPS) to prevent data loss and other system file integrity issues caused by unexpected power interruption. Back up the system files in the planned way to prevent data loss and other system file integrity issues caused by incorrect operation.



Additional Information

- The selected conductor size must match with the used maximum power supply capacity or an overcurrent protection device must be used.
- The used wires and the overcurrent protection device must meet the applicable national standards.

Standards are:

- NEC (National Electric Code)
- CEC (Canadian Electrical Code)
- international applicable standards
- Refer to 4-1-2 General Electrical Specifications on page 4-3 for electrical specifications.
- Refer to 4-1-3 Power Consumption Specifications on page 4-4 for power consumption specifications.
- Refer to 2-9-9 UPS on page 2-21 for UPS information.


Power Connector Wiring Materials

Use the power supply connector that was supplied to connect the power supply to the IPC RTOS Controller.

- Select power supply conductors with consideration to the voltage drop and heat generation for the cable length at the installation environment.
- Always use twisted wires to minimize the occurrence of electrical disturbance.
- · Recommended power supply conductor sizes are provided in the table.

Wire type	Conductor cross-section
Solid conductor	0.5 to 10 mm ²
Flexible conductor	0.5 to 6 mm ²
Flexible conductor, with ferrule and no plastic sleeve	0.5 to 6 mm ²
Flexible conductor, with ferrule and plastic sleeve	0.5 to 4 mm ²
Minimum AWG according to UL/cUL	20
Maximum AWG according to UL/cUL	8

Power Supply Connector



DC Power Supply

The OMRON S8VK-series power supply is recommended for use with the IPC RTOS Controller.




Additional Information

- Refer to 2-9-8 Power Supply on page 2-20 for more information.
- Refer to 4-1-3 Power Consumption Specifications on page 4-4 for power consumption details.

Power Connector Wiring Procedure

Use the following procedure to wire the power connector.



3 Remove the screwdriver.

Do not apply stress to the cable after you have connected the wires.

5-4-4 Wire the I/O Connector

This section describes how to wire the I/O connector.


I/O Connector Wiring Materials

Use the supplied I/O connector to connect the inputs and outputs to the IPC RTOS Controller. Recommended I/O conductor sizes for the connector are provided in the table.

Wire type	Conductor cross-section
Solid conductor	0.2 to 1.5 mm ²
Flexible conductor	
Flexible conductor, with ferrule and no plastic sleeve	0.25 to 1.5 mm ²
Flexible conductor, with ferrule and plastic sleeve	0.25 to 0.75 mm ²
Minimum AWG according to UL/cUL	24
Maximum AWG according to UL/cUL	16

I/O Connections

This section describes I/O connection details.



Pin	Description	Internal Circuit Details
1	Power Status Output	The Power Status Output has an internal relay. Wire this
2		according to the input device connected to the Power Sta-
		tus Output.

Pin	Description	Internal Circuit Details
3	Power ON Input	The Power ON Input and the UPS Mode Input are bi-di-
4		rectional and isolated. Each input can be wired as sinking
5	UPS Mode Input	(NPN) or sourcing (PNP). Wire these according to the
6		output device connected to the inputs.



Additional Information


- Refer to 4-2-2 I/O Connector Specifications on page 4-11 for I/O connector specifications.
- Refer to I/O Connector Power Status Output Details on page 4-13 for power status output details.
- Refer to 2-9-9 UPS on page 2-21 for UPS information.

I/O Connector Wiring Procedure

Use the following procedure to wire the I/O connector.

- Remove the sheath from the wires.
 Precautions for Safe Use
 Observe the following precautions to prevent broken wires.
 When you remove the sheath, be careful not to damage the conductor.
 Connect the conductor without twisting the wires.
 Do not weld the conductors. Doing so may cause the wires to break with vibration.

 2 Remove the I/O connector from the Box PC.
- Insert a screwdriver in the small groove above the cable entry 1 to unlock the cable entry and then push the wire all the way to the back of the cable opening 2.



4 Remove the screwdriver.


Do not apply stress to the cable after you have connected the wires.

5

5-5 Connect

This section describes how to connect the IPC RTOS Controller.

5-5-1 Connector Identification



The Industrial Box PC connectors are shown below.

Item	Name	Description
А	Power connector	Lockable power connector
В	I/O connector	2 inputs (UPS signal and power OFF control) and 1 output (Industri- al Box PC power state)
С	USB 3.0 connector	2 USB 3.0 connectors
D	USB 2.0 connector	2 USB 2.0 connectors
E	10BASE-T/100BASE-TX/ 1000BASE-T Ethernet connec- tors	3 RJ45 Gb Ethernet connectors
F	DVI connector	Digital Visual Interface connector

ltem	Name	Description
G	Option port	Interface connection options for peripheral devices or an additional monitor: • RS-232C connector (default) • DVI-D connector • NY Monitor Link connector

5-5-2 Connection Procedure

Use the following procedure to connect the IPC RTOS Controller.

Ensure the Box PC is securely fastened to the mounting surface.

Ensure the mounted Box PC can be connected to power and peripheral devices. Remove dust covers where applicable and store them in a safe place.




Additional Information

- Refer to 5-3 Mount on page 5-14 for mounting details.
- · Refer to:
 - 2-9-5 DVI Cables on page 2-19
 - 2-9-6 USB Type-A to USB Type-B Cables on page 2-19
 - · individual cable specifications
 - for cable bending requirements and connector clearance.

Use the following procedure to connect the Box PC:


- Ensure the ground terminal is connected.Refer to 5-4-2 Ground on page 5-29 for grounding details.
- 2 Connect the power connector (A). Hold the black part to enable the auto-locking mechanism.



Do not push the orange sliders $^{\textcircled{B}}$ in the direction of the Box PC because this will unlock the connector.

3 Connect the I/O connector.

Hold the black part (A) when inserting the connector, this enables the auto-locking mechanism.



Do not tilt the orange levers $^{\textcircled{B}}$ because this will unlock the connector.

4 Connect an external monitor such as the Industrial Monitor. Connect the monitor to the DVI connector and tighten the fastening screws or use the optional NYML connector.

For an Industrial Panel PC this is optional because a monitor is integrated.

- **5** Connect a device to the optional interface (DVI, RS-232C or NYML) if applicable and tighten the fastening screws when applicable.
- **6** Connect the USB ports to peripheral devices .

Connect the Box PC to the required Ethernet interface connector(s).
 Refer to 4-2-4 Ethernet Connector Specifications on page 4-15 for Ethernet port details.
 The Box PC is connected.

5-6 Initial Power ON

This section describes how to Power ON the IPC RTOS Controller for the first time.

Ensure that installation and post-installation checks of the product are performed by personnel in charge who possess a thorough understanding of the machinery to be installed.



5-6-1 Initial Power ON Procedure

Use the following procedure to power ON the IPC RTOS Controller for the first time.

- 1 Ensure the following conditions are present before applying power for the first time:
 - The Box PC is securely fastened to the mounting surface.
 - The Box PC is connected to ground.
 - All connectors are securely fastened.
- **2** Ensure that the connected monitor(s) is powered ON.
- **3** Connect a keyboard and/or a mouse.



Additional Information

- If using an OMRON Industrial Monitor this may not be required because it has touch functionality.
- Do not connect additional storage devices before the installation of the operating system completed. Adding storage devices like a USB flash drive, an SD memory card or a PCIe card might influence the default drive letter sequence.



Ensure the power supply is ON.

Precautions for Safe Use

Always check the power supply and power connections before applying power. Incorrect power connections can damage the product or cause burning.

5 Press the power button and release within 1 second. Refer to 2-3 *Power Button* on page 2-7 for the power button location. The Box PC starts and the PWR LED will go ON.



Additional Information

- Do not connect or disconnect the DVI-D cable while power is supplied to the Box PC.
- · If a Windows operating system is preinstalled:
 - · the Windows configuration will automatically start
 - refer to Windows Startup First Time for details



The Box PC is ON and if an operating system is installed it will start.

Precautions for Safe Use

Always use the SMART monitoring feature for storage devices that do not comply to the Omron Storage Device Specifications. Monitor the operating temperature and vibrations to ensure they stay within the environmental specifications of the storage device.



Additional Information

- The first time initialization will prepare the system and automatically reboot the Box PC when required.
- Install support software to fully utilize your Box PC and optional connected hardware like the Industrial Monitor.

5-7 Connect UPS

The OMRON S8BA UPS protects the Box PC from power failures, voltage variations and instantaneous voltage drops. Short power interruptions will be backed up by the UPS and the Box PC will continue normal operation. The UPS signals the Box PC when a power failure occurs and then the Box PC will shutdown normally without data loss. The Box PC can automatically start up again when the power is restored.

The use of an uninterruptible power supply (UPS) allows normal operation to continue even if a momentary power failure occurs, possibly resulting in the reception of an erroneous signal from an external device affected by the momentary power failure. Take external fail-safe measures. Where necessary, monitor the power supply voltage on the system for external devices and use it as an interlock condition.





Precautions for Safe Use

- Always use an uninterruptable power supply (UPS) to prevent data loss and other system file integrity issues caused by unexpected power interruption.
- Use an Omron S8BA UPS with the correct revision number to prevent improper system shutdown.
- Correctly perform wiring and setting, and ensure that the shutdown by the UPS can be executed.



Additional Information

- The minimum power requirements of the UPS are dependent on the power consumption. Refer to *4-1-3 Power Consumption Specifications* on page 4-4 for power consumption details.
- Refer to the OMRON website for S8BA specifications and for the UPS S8BA User's Manual (Cat. No. U702).

Note that the power consumption details determine the output current/capacity of your UPS.

5-7-1 Connect UPS Using the USB Connector

The Simple Shutdown Software monitors the UPS status via the USB interface and shuts down the IPC RTOS Controller when needed.

The drivers for the S8BA UPS and the installation files for the Simple Shutdown Software are available on the OMRON website.



Precautions for Safe Use

- Use an Omron S8BA UPS with the correct revision number to prevent improper system shutdown.
- Correctly perform wiring and setting, and ensure that the shutdown by the UPS can be executed.
- Always use the recommended uninterruptible power supply (UPS) to prevent data loss and other system file integrity issues caused by unexpected power interruption. Back up the system files in the planned way to prevent data loss and other system file integrity issues caused by incorrect operation.

Follow the steps below to connect the S8BA UPS with a USB cable and to configure it correctly. Before proceeding with the steps below, check if the revision number of the UPS is correct. Refer to 2-9-9 UPS on page 2-21 for more information.


5

5-7 Connect UPS

1 Install and connect the S8BA UPS.

Refer to the UPS S8BA User's Manual (Cat. No. U702) for details.

Connect the USB port of the S8BA UPS to the USB port of the IPC RTOS Controller using the USB cable provided with the S8BA UPS.



- **2** Power ON the IPC RTOS Controller and Proceed to the next step after the device drivers are successfully installed.
- **3** Install the Simple Shutdown Software.

Configure the Simple Shutdown Software.
 Refer to the Simple Shutdown Software Instruction Manual (Cat. No. K1LD) for more information.

5 Configure the IPC RTOS Controller to auto-start after power loss within the BIOS settings.

- Refer to A-1-1 BIOS Overview on page A-2 for details on BIOS changes.
- Refer to A-1-5 BIOS Boot on page A-10 for power loss BIOS details.

The UPS is connected.



Additional Information

The default **Input sensitivity setting** is **Standard voltage sensitivity** and this is correct. Do not set this parameter to **Low voltage sensitivity**. Doing so can cause a system malfunction when switching to battery mode.

Operating Procedures

This section provides the operating procedures for the IPC RTOS Controller.

6-1	Power	ON	. 6-2
	6-1-1	Power ON Using the Power Button	
	6-1-2	Power ON Using the Power ON/OFF Input	. 6-2
	6-1-3	Auto Power ON	. 6-2
6-2	Power	OFF	. 6-3
	6-2-1	Power OFF Using the Operating System Shut Down	. 6-3
	6-2-2	Power OFF Using the Power Button	
	6-2-3	Power OFF Using the Power ON/OFF Input	. 6-4
	6-2-4	Forced Power OFF Using the Power Button	. 6-4

6-1 Power ON

This section provides Power ON details.

6-1-1 **Power ON Using the Power Button**

Start condition: Power is supplied to the Box PC and the Box PC is OFF.

1

Press the power button and release within 1 second. Refer to 2-3 *Power Button* on page 2-7 for the power button location. The Box PC starts and the PWR LED will turn ON.

2 Wait until the PWR LED is ON and verify that the ERR LED is OFF. The Box PC is ON and the Operating System, if installed, starts.

6-1-2 Power ON Using the Power ON/OFF Input

Start condition: Power is supplied to the Box PC and the Box PC is OFF.

Supply an input signal to pins 3 and 4 of the I/O connector. The input signal must remain ON for a minimum of 60 ms and a maximum of 750 ms to be correctly detected by the Box PC. The Box PC starts and the PWR LED will turn ON.

2 Wait until the PWR LED is ON and verify that the ERR LED is OFF. The Box PC is ON and the Operating System, if installed, starts.



Additional Information

- Refer to 4-2-2 I/O Connector Specifications on page 4-11 for connector specifications.
- Refer to 5-4-4 Wire the I/O Connector on page 5-39 for wiring details.

6-1-3 Auto Power ON

The Box PC can be configured to start up when power is supplied to the power connector. The **Power Loss Control** BIOS setting controls this behavior.

Set the Power Loss Control setting to Turn ON to activate the Auto Power ON function.



Additional Information

Refer to A-1-5 BIOS - Boot on page A-10 for BIOS details.

6-2 Power OFF

This section provides Power OFF details.

Before following power OFF procedures below, check that the IPC RTOS Controller is ON by examining the LED indicators on the Box PC.

6-2-1 Power OFF Using the Operating System Shut Down

1 Ensure all programs are closed. If required close all active programs.

2 Select **Shut down** of the Operating System. The Box PC will shut down.

3 Wait until the PWR LED is OFF. The Box PC is powered OFF.

6-2-2 Power OFF Using the Power Button

- Ensure all programs are closed.
 If required close all active programs.
- Press and release the power button on the IPC RTOS Controller within 1 second. The IPC RTOS Controller will shutdown.
 Note that this behaviour of can be reconfigured with the Power Options settings.
 Refer to 2-3 Power Button on page 2-7 for power button location information.

3 Wait until the PWR LED is OFF. The Box PC is powered OFF.



Additional Information

The Box PC will restart automatically if a UPS is connected to the I/O connector of the Box PC. Use the Power button of the UPS or remove the input power from the UPS for a normal shutdown of the Box PC.

6-2-3 Power OFF Using the Power ON/OFF Input

- Ensure all programs are closed.
 If required, close all active programs.
- 2 Supply a 24 VDC signal to the Power ON/OFF Input (pins 3 and 4) of the I/O connector. The input signal must remain ON for a minimum of 60 ms and a maximum of 750 ms to be correctly detected by the IPC RTOS Controller. The IPC RTOS Controller will shutdown.
 - Note that this behaviour can be reconfigured with the Power Options settings.



The Box PC is powered OFF.



Additional Information

- Refer to 4-2-2 I/O Connector Specifications on page 4-11 for connector specifications.
- Refer to 5-4-4 Wire the I/O Connector on page 5-39 for wiring details.

6-2-4 Forced Power OFF Using the Power Button

Precautions for Safe Use

Press the power button for several seconds to force the product shutdown. Always back up files in the planned way to prevent data loss or system file corruption.



Ensure all programs are closed.

If required, close all active programs to prevent losing unsaved data.

- Press and hold the power button on the Box PC for 5 to 10 seconds.
 Refer to 2-3 Power Button on page 2-7 for power button location information.
 The IPC RTOS Controller will power OFF.
 Any optional operating system settings related to power OFF will be disregarded.
- **3** Wait until the PWR LED is OFF.

The Box PC is powered OFF.

Confirm normal operation and check all product settings because unsaved data was lost.

Maintenance

This section provides an overview of all maintenance tasks for the IPC RTOS Controller.

7-1	Preventive Maintenance		
	7-1-1	Preventive Maintenance Schedule	7-2
	7-1-2	Clean the Box PC	7-4
	7-1-3	Keep Software Updated	7-4
7-2	Correc	tive Maintenance	
	7-2-1	Warning and Error Messages	7-5
	7-2-2	Remove the Cover	7-6
	7-2-3	Replace the Fan Unit	7-7
	7-2-4	Replace the Battery	7-9
	7-2-5	Replace a Drive	.7-11
	7-2-6	Replace the PCIe Card	7-16

7-1 Preventive Maintenance

Preventive Maintenance covers all actions that prevent downtime.

7-1-1 **Preventive Maintenance Schedule**

Prevent unscheduled downtime with the following preventive maintenance schedule.

Daily	Reference
Check IPC RTOS Controller status	 Refer to 7-2-1 Warning and Error Messages on page 7-5 for Box PC Messages. Refer to 2-2 LED Indicators on page 2-5 for LED details.
Monitor storage devices that do not comply to the Omron specifications	Refer to Storage Device Considerations on page 2-18 for details.

Weekly	Reference
Clean the Box PC	Refer to 7-1-2 Clean the Box PC on page 7-4 for cleaning details.
Ensure you have the latest soft- ware updates	Refer to 7-1-3 Keep Software Updated on page 7-4 for update details.

When changing applications or configurations	Reference
Create a backup of the IPC RTOS	
Controller	

Periodically but at least every 6 months	Reference
 Check the ambient environment: Temperature and humidity within specifications Noise sources not close to the IPC RTOS Controller 	Refer to <i>4-3 Environmental Specifications</i> on page 4-20 for environmental specifications.
Check installation: IPC RTOS Controller mounted se- curely	Refer to <i>5-3 Mount</i> on page 5-14 for installation details.
 Check wiring and connections: Cable connectors fully inserted and locked No damaged wiring or connec- tors 	Refer to <i>5-4 Wire</i> on page 5-28 for wiring details. Refer to <i>5-5 Connect</i> on page 5-42 for connection details.
Check the battery replacement date on the label at the inside of the Cover. Replace the battery before the re- placement date.	 Refer to 7-2-2 Remove the Cover on page 7-6 to check the label. Refer to 7-2-4 Replace the Battery on page 7-9 to replace the battery.
Check that the backup of the IPC RTOS Controller is available and operational.	

When the Box PC is not powered for 6 months	Reference
Confirm both fans rotate immedi- ately after Power ON. Replace the Fan Unit when the fans do not rotate smoothly.	Refer to 7-2-3 <i>Replace the Fan Unit</i> on page 7-7 to replace the Fan Unit.

7

7-1-2 Clean the Box PC

Clean the Box PC periodically in order to keep it in the best operating condition. Wipe the Box PC with a dry, soft cloth.



Precautions for Safe Use

Do not use corrosive substances to clean the product. Doing so may result in the failure or malfunction.

7-1-3 Keep Software Updated

Always keep software at the latest released version to ensure stable operation. This is specifically important for:

- Internet browser
- · Operating system security patches
- · OMRON software



Precautions for Correct Use

After an OS update or a peripheral device driver update for the product is executed, the product behavior might be different. Confirm that operation is correct before you start actual operation.

7-2 Corrective Maintenance

Corrective maintenance covers all actions to correct problems that cause downtime.

WARNING

Do not attempt to disassemble, repair, or modify the product in any way. Doing so may result in malfunction or fire.

Contact your local OMRON representative if the corrective maintenance actions did not solve the problem.

7-2-1 Warning and Error Messages

Warning and Error messages are provided by the IPC RTOS Controller when there is a potential problem that may cause downtime. This section provides details about these messages. Warning messages inform you about a situation that will lead to downtime of the IPC RTOS Controller. Error messages inform you about what caused the downtime of the IPC RTOS Controller.

The following message channels are available.

LED Indicators

The ERR LED indicator provides information on warnings and errors.



Additional Information

Refer to 2-2-2 ERR LED Indicator on page 2-6 for ERR details.

7-2-2 Remove the Cover

The Cover of the IPC RTOS Controller provides access to the following items.

- · Battery
- Fan Unit (applies to products with active cooling)

The inside of the Cover contains the following information.

- · Battery replacement date
- · License key for the operating system (optional)

No tools are required to open the Cover.

Use the following procedure to remove the Cover of the Box PC.


1 Power OFF your Box PC if it has active cooling.



Precautions for Safe Use

Do not remove the fan cover while the power is ON. Contact with the rotating fan may result in injury.

2 Remove the Cover.



- 1) Pull the lever 1 to unlock the Cover.
- 2) Lift the side **2** to tilt the Cover.
- 3) Remove **3** the complete Cover.

The Cover is removed.

To mount the Cover, position the side of the Cover in the Box PC and push the cover in place. The lever will lock in place.

7-2-3 Replace the Fan Unit

The fans are mounted in the Fan Unit.

Use the following procedure to replace the Fan Unit.



Precautions for Safe Use

If the replacement Fan Unit has been stored over 6 months then check the performance of the Fan Unit after replacement.



Additional Information

Refer to 2-8-2 Fan Unit on page 2-15 for the model.


- **1** Power OFF the Box PC.
- **2** Remove the Cover of the Box PC.





Additional Information

Refer to 7-2-2 Remove the Cover on page 7-6 for the cover removal procedure.

3 Disconnect the Fan Connectors from the board.








- 1) Push the lever 1 to unlock the Fan Unit.
- 2) Lift the lever to tilt **2** the Fan Unit.
- 3) Remove ③ the complete Fan Unit.
- 5 Insert the new Fan Unit in the Box PC.

Ensure the end of the Fan Unit A is positioned under the fan guide B.





Connect the Fan Connectors to the board.



Mount the Cover.



Power ON the system.

Confirm both fans rotate immediately after Power ON.

The fans are replaced and the alarm is automatically reset.

7-2-4 Replace the Battery



Precautions for Safe Use

- The Battery may leak, rupture, heat, or ignite. Never short-circuit, charge, disassemble, heat, or incinerate the Battery or subject it to strong shock.
- Dispose of any Battery that has been dropped on the floor or otherwise subjected to excessive shock. Batteries that have been subjected to shock may leak if they are used.
- UL standards require that only an experienced engineer replace the Battery. Make sure that an experienced engineer is in charge of Battery replacement.



Precautions for Correct Use

- Always touch a grounded piece of metal to discharge static electricity from your body before starting an installation or maintenance procedure.
- Make sure to use a battery of the correct type and install the battery properly.
- Apply power for at least five minutes before changing the battery. Mount a new battery within
 five minutes after turning OFF the power supply. If power is not supplied for at least five minutes, the clock data may be lost. Check the clock data after changing the battery.
- Turn ON the power after replacing the battery for a product that has been unused for ax extended period of time. Leaving the product unused without turning ON the power even once after the battery is replaced may result in a shorter battery life.



Additional Information

• Refer to 2-8-1 Battery on page 2-15 for the battery model.

Use the following procedure to replace the battery:




Remove the cover.



Additional Information

Refer to 7-2-2 Remove the Cover on page 7-6 for the cover removal procedure.

- **3** Lift the battery **1** from the compartment.
- **4** Disconnect the battery from the battery connector **2**.



- **5** Connect the new battery to the battery connector.
- **6** Place the new battery in the Box PC. Ensure the wires are at the side of the battery and not on top of the battery. If the wires are on top of the battery this might make closing and opening the cover more difficult.
- 7 Write the next date of replacement on the label at the inside of the cover.



Additional Information

Refer to 2-8-1 Battery on page 2-15 for lifetime of the battery.

8 Mount the cover.

9 Remove the power connector for at least 3 seconds to reset the battery warning.

10 Power ON the Box PC.

11 Check the Date and Time in the operating system. Correct the Date and Time if this is required.

The battery is replaced and the alarm is reset.

7-2-5 Replace a Drive

Use the following procedure to replace a drive.

Prepare the new drive.




Additional Information

- Refer to 1-4 Product Configuration on page 1-5 for the installed drive model.
- Refer to 2-9-4 Storage Devices on page 2-18 for the available drive models.
- Refer to 4-1-6 Storage Device Specifications on page 4-6 for drive specifications.

To replace a drive:

- **1** Power OFF the Box PC.
- **2** Remove the drive cover.




- 1) Push the lock lever **1**.
- 2) Tilt the cover **2**.
- 3) Remove the drive cover ³.



Additional Information


- Refer to 2-4 Drive Bays on page 2-8 for the location of the drive cover.
- The Box PC has 2 drive bays, marked with "A" and "B" at the left side of the drive cover. Take
 note of the bay position for the drive that is being removed and do not place a drive in the
 incorrect bay.


7



3 Pull the metal shielding cover out of the Box PC.


4 Insert the drive cover in the drive bracket bay 1 and move it down 2 so that it locks in the drive bracket.






5 Remove the drive bracket from the Box PC using the drive cover.

6 Remove the 4 mounting screws **1** and then remove the drive **2** from the drive bracket.




7

Align the connectors of the replacement drive as shown on the bracket. Then insert the replacement drive in the bracket and insert the 4 mounting screws in the screws with a torque of 0.35 N·m.




8 Insert the bracket with the replacement drive into the correct bay of the Box PC. Ensure the bracket is completely in the Box PC with an extra push.



The drive bracket will lock into place when it is fully inserted.




Insert the metal shielding cover.



10 Mount the drive cover.

The lock lever will click when closed correctly.



11 Restore the drive data.

- For products *NYB* and *NYP*::
 - For an Industrial PC with RTOS Controller restore the drive data from a backup.
 - For an Industrial PC without Operating System restore the drive data from a backup.
 - For an Industrial PC with a Windows operating system refer to the restore procedure in the section *Corrective Maintenance* to restore data.
- For products *NY512-A* refer to the restore procedure in the section *Corrective Maintenance* to restore data.
- For products NY512-1 refer to the NY-series IPC Machine Controller Industrial Panel PC / Industrial Box PC Setup User's Manual (Cat. No. W568) to restore data from a backup.

12 Finalize the drive replacement.

If the Box PC has a Windows operating system and the storage drive is not visible in Windows then the drive needs to be allocated.

The drive is replaced.

7

7-2-6 Replace the PCIe Card

Use the following procedure to replace the PCIe Card.

Prepare:

The PCIe Card



Additional Information

Refer to 4-1-7 PCIe Card Specifications on page 4-8 for PCIe specifications.

• The PCIe Card mounting materials: Card Clip and Card Support These are supplied with the IPC RTOS Controller.


To replace the PCIe Card:

1 Power OFF the system.




- Unmount the Box PC.
- **3** Remove the two crosshead screws **1** indicated with "open" and then pull up **2** the PCIe Drawer.


The indent at the side of the drawer will help you to pull the drawer from the Box PC.



4 Push the notch • at the bottom of the Card Support up and rotate • the Card Support.Slide the Card Support • away from the card to create space and to remove it.




5 Pull the middle of the Card Clip to unlock it and remove it from the PCIe Drawer.




7

6 Remove the PCIe Card from the PCIe Drawer.




The PCIe Card is now removed.

7 Place the replacement PCIe Card in the PCIe Drawer.




Ensure the PCIe Card is inserted into the correct opening.

8 Place the Card Clip in the PCIe Card and PCIe Drawer 1 and then rotate the Clip 2 to lock it in place.




9 Slide the Card Support ¹ so that it supports the side of the PCIe Card.
Rotate the Card Support ² to lock it in place.



Ensure the Card Support contacts the PCIe Card with the small groove so that there is support below and above the PCIe Card.

10 Insert the PCIe Drawer in the Box PC and then insert the two crosshead screws that hold the PCIe Drawer in place.



11 Remount the Box PC.

12 Confirm normal operation. The PCIe Card is replaced.

A

Appendices

A-1	BIOS .		A-2
		BIOS Overview	
		BIOS - Main	
	A-1-3	BIOS - Advanced	A-4
	A-1-4	BIOS - Chipset	A-9
	A-1-5	BIOS - Boot	
	A-1-6	BIOS - Security	A-11
	A-1-7	BIOS - Save & Exit	A-11
A-2	DVI-D	Connector Pin Details	A-12
A-3	RS-23	2C Connector Pin Details	A-13

A-1 BIOS

This section provides the BIOS information of the IPC RTOS Controller.

Changing BIOS information is only allowed for the engineer in charge that possesses a thorough understanding of the BIOS settings because it can change the behavior of the product.



A-1-1 BIOS Overview

The BIOS contains settings that influence the behavior of the IPC RTOS Controller. The touchscreen functionality is not functional when working in BIOS. Ensure a USB keyboard is connected.

BIOS Setup Program

Press the DEL or F2 key repeatedly directly after Power ON to access the BIOS Setup Program.

Boot Selection Popup Menu

Press the **F11** key repeatedly directly after Power ON to display the Boot Selection Popup menu. The popup menu allows selection of the boot device and the option to enter the BIOS setup program.

BIOS Structure

The BIOS contains a menu bar, a left frame and a right frame.

The left frame displays all the options that can be configured in the selected menu.

The left frame uses following colors:

- Blue = Configurable options
- Greyed-out = Not configurable
- Inverse white = Selected

The right frame displays the key legend. Above the key legend is an area reserved for text messages. These text messages explain the options and the possible impacts when you change the selected option in the left frame.

Use the $\rightarrow \leftarrow$ keys to navigate between pages.

The menu bar gives access to following pages with settings:

• Main

Refer to A-1-2 BIOS - Main on page A-4 for Main details.

Advanced

Refer to A-1-3 BIOS - Advanced on page A-4 for Advanced details.

- Chipset
- Refer to A-1-4 BIOS Chipset on page A-9 for Chipset details.
- Boot

Refer to A-1-5 BIOS - Boot on page A-10 for Boot details.

- Security Refer to A-1-6 BIOS - Security on page A-11 for Security details.
 Save & Exit
 - Refer to A-1-7 BIOS Save & Exit on page A-11 for Save and Exit details.

BIOS - Navigation and Function Keys

The right part of the BIOS screens is divided in two parts.

Top part.

Provides additional information on selected screens or parameters.

Bottom part.

Provides information on Keys.

• →← : Select Screen

Changed between different BIOS pages.

↑↓ : Select Item

Changed between different parameters.

Enter: Select

Selects the parameter that has the focus and displays a submenu or the possibility to change the parameter.

+ / - : Change Option

Change settings. A numerical value will be increased or decreased. A boolean value will toggle.

- F1: General Help Displays help information.
- F2: Previous Values Changes all parameters to the values they had when entering the BIOS.
- F9: Optimized Defaults Changes all settings to the default values.
- F10: Save & Exit

Saves all changes and exits the BIOS.

• ESC: Exit Go one level up. For parameters this is the previous level. For the main pages this exits the BIOS.

BIOS Password & Write Protection

A BIOS password protects the BIOS setup program from unauthorized access. This ensures that users cannot change the system configuration without authorization. With an assigned BIOS password, the BIOS prompts the user for a password on a setup entry. If the password entered is wrong, the BIOS setup program will not launch.

The BIOS uses encryption for the password.

The BIOS password is case sensitive with a minimum of 3 characters and a maximum of 20 characters. Once a BIOS password has been assigned, the BIOS activates the grayed out **BIOS Update and Write Protection** option. If this option is set to **enabled**, only authorized users (users with the correct password) can update the BIOS. With the BIOS password protection and the BIOS update and write protection, the system configuration is completely secured. If the BIOS is password protected, you cannot change the configuration of an end application without the correct password.

A-1-2 BIOS - Main

The main setup screen gives platform information about the BIOS, Board Information, Firmware Revision, MAC Addresses and information about the number of Boots and the Running Time.

Changeable BIOS Main parameters and their factory default values:

- System Date Use the Enter key to the next Date field.
- System Time Use the Enter key to the next Time field.

A-1-3 BIOS - Advanced

This section provides advanced BIOS information.

Changeable BIOS Advanced parameters and their factory default values:

	Default / Remark	
Machine Control ^{*1}		Disabled
Graphics	Primary Graphics Device	Auto
	Internal Graphics Device	Auto
	IGD Pre-Allocated Graphics Memory	32M
	IGD Total Graphics Memory	256M
	Primary IGD Boot Display Device	Auto
	Active LFP Configuration	eDP / for Industrial
		Panel PC
		 No Local Flat Panel /
		for Industrial Box PC
	Digital Display Interface 1	HDMI/DVI
	Digital Display Interface 2	HDMI/DVI
Hardware Health Start Temperature		50 C
Monitoring *1	Temperature Range	30 C
	Minimum Fan Speed	30% / Fixed
	Maximum Fan Speed	100%
	Fan Always On At Minimum Speed	Disabled

	Default / Remark		
PCI & PCI Express	PCI Latency Timer		32 PCI Bus Clocks
	PERR # Generation		Disabled
	SERR # Generation		Disabled
	PIRQ Routing & IRQ Res- ervation	PIRQA,B,C,D,E,F,G,H	Auto
	PCI Express Settings	Relaxed Ordering	Disabled
		Extended Tag	Disabled
		No Snoop	Enabled
		Maximum Payload	Auto
		Maximum Read Request	Auto
		ASPM	Disabled
		Extended Synch	Disabled
		Link Training Retry	5
		Link Training Timeout (us)	100
		Unpopulated Links	Disabled
		Restore PCIe Registers	Disabled

A

	Item		Default / Remark
PCI & PCI Express	PCI Express Gen 2 Set-	Completion Timeout	Default
	tings	ARI Forwarding	Disabled
		AtomicOp Requester En- able	Disabled
		AtomicOp Egress Block- ing	Disabled
		IDO Request Enable	Disabled
		IDO Completion Enable	Disabled
		LTR Mechanism Enable	Disabled
		End-End TLP Prefix Blocking	Disabled
		Target Link Speed	Auto
		Clock Power Manage- ment	Disabled
		Compliance SOS	Disabled
		Hardware Autonomous Width	Enabled
		Hardware Autonomous Speed	Enabled
	PCI Express Gen3 Set-	Run-time C7 Allowed	Disabled
	tings (for Port 0 and 1) ^{*1}	Detect Non-compliant De- vice	Disabled
		Program PCIe ASPM af- ter OpROM	Disabled
		PEG Sampler Calibrate	Disabled
		Swing Control	Full
		Peg Gen3 Equalization	Enabled
		- Gen3 EQ Phase 2	Enabled
		- PEG Gen3 Root Port Preset Value for each Lane. Lane 015	8
		- PEG Gen3 Endpoint Preset Value for each	7
		Lane. Lane 015 - PEG Gen3 Endpoint Hint Value for each Lane.	2
		Lane 015	
		- Gen3 Eq Preset Search	Enabled
		– Always Re-search Gen3	Disabled
		Eq Preset	
		– Preset Search Dwell Time	1000
		– Error Target	1
		PEG RxCEM Loopback Mode	Disabled
		PCIe Gen3 RxCTLEp Setting. PCIe Gen3	8
		RxCTLEp 07	

Item			Default / Remark
PCI & PCI Express	GbE Channel 0	PCI Express Port 0	Enabled
		ASPM	Disabled
	GbE Channel 1	PCI Express Port 1	Enabled
		ASPM	Disabled
	PCI Express Port 0, 1 (x4	PEG1 Speed	Auto
	Gen3) ^{*4}	PEG1 ASPM	Disabled
		PEG1 De-emphasis Con- trol	-3.5 dB
	PCI Express Port 2, 3, 4,	PCI Express Port x	Enabled
	5 (x1 Gen2) ^{*4}	ASPM	Disabled
		Hot Plug	Disabled
		PCIe Speed	Auto
		Detect Non-compliant De-	Disabled
		vice	
ACPI	Hibernation Support		Disabled
	ACPI Sleep State		Suspend Disabled
	Lock Legacy Resources		Disabled Disabled
	S3 Video Repost	eo Repost	
	ACPI Low Power S0 Idle *3 *2		Disabled
	Native PCI Express Suppo	Native PCI Express Support	
	- Native ASPM	- Native ASPM	
	ACPI Debug		Disabled
	ACPI 5.0 CPPC Support	ACPI 5.0 CPPC Support	
	Active Trip Point *3 *2	Active Trip Point *3 *2	
	Automatic Critical Trip Point		Enabled
RTC Wake	Make System At Fixed Tim	e	Disabled
Trusted Computing	Security Device Support		Enable
	TPM State	TPM State	
	Pending operation		None

Α

	Item		Default / Remark
CPU	CPU Information		Display of CPU parame-
			ters
	Set Boot Freq Ratio		255
	Hyper-Threading *2 *1		Enabled
	Active Processor Cores	Active Processor Cores	
	Limit CPUID Maximum		Disabled
	Execute Disable Bit	Execute Disable Bit	
	Intel Vitalization Technolog	у	Enabled
	Hardware Prefetcher		Enabled
	Adjacent Cache Line Prefe	tch	Enabled
	CPU AES *2 *1		Enabled
	EIST		Enabled
	- Turbo Mode *2 *1		Enabled
	- Energy Performance *2 *1		Performance
	P-State Reduction *3		Disabled
	CPU C States		Disabled
	TCC Activation Offset		0
	Intel TXT(LT) Support *2 *1		Disabled
SATA	SATA Controller(s)		Enabled
	SATA Mode Selection		AHCI
	SATA Test Mode		Disabled
	Aggressive LPM Support		Disabled
	SATA Controller Speed		Default
	Serial ATA Port 0, 1, 2, 3	SATA Port	Enabled *5
	*5	Hot Plug	Disabled
		External SATA	Disabled
		SATA Device Type	Hard Disk Drive
		Spin Up Device	Disabled
Memory Configuration			Display of memory pa- rameters
Intel (R) Rapid Start Tech	nology		Disabled
USB	XHCI Mode		Smart Auto
	Overcurrent Protection		Disabled
	USB Ports Per-Port Disa-	USB Ports Per-Port Disa-	Enabled
	ble Control	ble Control	
		- USB Port 06	Enabled
		- USB 3.0 Port 01	Enabled
	Legacy USB Support		Enabled
	External USB Controllers Support		Enabled
	XHCI Hand-off		Enabled
	EHCI Hand-off		Disabled
	USB Mass Storage Driver	Support	Enabled
	USB Transfer Timeout		20 sec
	Device Reset Timeout		20 sec
	Device Power-up Delay Se	election	Auto
	Generic Ultra HS-COMBO		Auto

Item			Default / Remark
SMART Settings	Smart Self Test ^{*6}		Disabled
UEFI Network Stack	UEFI Network Stack		Disabled
NVMe Configuration		No NVME device found	
Intel® Ethernet	NIC Configuration	Link Speed	Auto Negotiated
Connection I218-LM -	Wake On LAN		Enabled
Unique MAC Address	Blink LEDs		0

- *1. Only for Box PCs with a CPU type Intel[®] Core[™] i7-4700EQ.
- *2. Only for Box PCs with a CPU type Intel[®] Core[™] i5-4300U.
- *3. Only for Box PCs with a CPU type Intel[®] Celeron[®] 2980U.
- *4. The active PCI Express Port number is related to the CPU type
 - Box PCs with an Intel[®] Core[™] i7-4700EQ CPU type use Port 0..5
 - Box PCs with an Intel[®] Core[™] i5-4300U CPU type use Port 2 and 3
 - Box PCs with an Intel[®] Celeron[®] 2980U CPU type use Port 2 and 3
- *5. Box PCs with an Intel[®] Celeron[®] 2980U CPU type only Port 0 and 1 are available
 - Box PCs with an Intel[®] Core[™] i5-4300U CPU type Port 1 is Disabled
 - Box PCs with an Intel[®] Core[™] i7-4700EQ CPU type Port 1 is Disabled. For Port 2: SATA Port = Enabled.
- *6. Smart Self Test monitors the status of the HDD/SSD. Enable only when Smart Monitoring software is used.

A-1-4 BIOS - Chipset

Provides Chipset settings.

Changeable BIOS Chipset parameters and their factory default values:

	Default / Remark	
Platform Controller Hub	PCI Express Clock Gating	Disabled
(PCH)	DMI Link ASPM PCH Side	Disabled
	DMI Link Extended Synch Control	Disabled
	Isolate SMBus Segments	During POST
	PCIe-USB Glitch W/A	Disabled
	USB Precondition	Disabled
	BTCG	Enabled
	HDA Controller	Auto
	HDA PME	Disabled
	PCH LAN Controller	Enabled
	Wake on LAN	Enabled
	Serial IRQ Mode	Continuous
	SB CRID	Disabled
	Port 80h Redirection	LPC Bus
	Subtractive Decode	Disabled
Processor (Integrated	VT-d *1 *2	Enabled
Components	Audio Device (B0:D3:F0)	Enabled
	NB CRID	Disabled
	BDAT ACPI Table Support	Disabled

*1. Only for Box PCs with a CPU type Intel[®] Core[™] i5-4300U.

*2. Only for Box PCs with a CPU type Intel[®] Core[™] i7-4700EQ.

A-1 BIOS

Α

A-1-4 BIOS - Chipset

A-1-5 BIOS - Boot

Provides Boot information and configuration settings.

Changeable BIOS Boot parameters and their factory default values:

Item		Default / Remark
Quiet Boot		Disabled
Setup Prompt Timeout		1
Bootup NumLock State		On
Battery Support		Auto (Battery Manager)
Power Loss Control *1		Remain Off
CSM & Option ROM Control	Launch CSM	Enabled
	Boot Option Filter	UEFI and Legacy
	PXE Option ROM Launch Policy	UEFI ROM Only
	Storage Option ROM Launch Policy	Legacy ROM Only
	Video Option ROM Launch Policy	Legacy ROM Only
	Other Option ROM Launch Policy	UEFI ROM Only
	Gate A20 Active	Upon Request
	Option ROM Messages	Force BIOS
Enter Setup If No Boot Device		No
Enable Popup Boot Menu		Yes
Boot Priority Selection		Type Based
Boot Option Sorting Method		Legacy First
Type Based Boot Priority	1st Boot Device	SATA 2 Drive *2
	2nd Boot Device	Disabled
	3rd Boot Device	Disabled
	4th Boot Device	Disabled
	5th Boot Device	Disabled
	6th Boot Device	Disabled
	7th Boot Device	Disabled
	8th Boot Device	Disabled
UEFI Fast Boot		Disabled

*1. Power Loss Control settings are :

Remain OFF: The IPC RTOS Controller will stay OFF when power is supplied to the power connector Turn ON: The IPC RTOS Controller will automatically start up when power is supplied to the power connector.

Last State: The IPC RTOS Controller will start up or remain OFF when power is supplied based on the IPC RTOS Controller state at the moment power was removed from the power connector.

*2. For Box PCs with a CPU type Intel[®] Celeron[®] 2980U: SATA 1 Drive

A-1-6 BIOS - Security

Provides security information like BIOS Password and HDD information.

Security setting adjustments should only be performed by the engineer in charge that possesses a thorough understanding of the security settings. Selecting non-recommended security settings can put your system at risk.



Changeable BIOS Security parameters and their factory default values:

Item			Default / Remark
BIOS Password	BIOS Password		
BIOS Lock			Enabled
HDD Security Configuration	Diskname	Diskname	
Secure Boot Menu	Secure Boot		Disabled
	Secure Boot Mode	Secure Boot Mode	
	Key Management	Key Management Default Key Provision	
		Platform Key (PK) Key Exchange Key (KEK)	
		Authorized Signatures	NOT INSTALLED
		Forbidden Signatures	NOT INSTALLED
		Authorized TimeStamps	NOT INSTALLED

A-1-7 BIOS - Save & Exit

Provides the possibility to leave the BIOS with or without saving changes.

Save & Exit Parameters: **Disabled**.

Save Changes and Exit

Changed settings are saved and the Operating System starts with the changed settings.

- Discard Changes and Exit Changed settings are not saved and the Operating System starts with the unchanged settings.
- Save Changes and Reset Changed settings are saved and the Box PC restarts using the changed settings.
- Discard Changes and Reset Changed settings are not saved and the Box PC restarts with the unchanged settings.
- Save Changes

Changed settings are saved and the BIOS setup stays open.

Discard Changes


Changed settings are reverted to their last saved values and the BIOS setup stays open.

Restore Defaults

Revert all BIOS settings to factory default.

A-2 DVI-D Connector Pin Details


Pin details of the DVI-D connector.



The pin layout represents the DVI connector on the IPC RTOS Controller. Pin numbers increase from left to right for every row.

Pin	Signal Name	Function	
1	TMDS data 2-	Digital red- (link 1)	
2	TMDS data 2+	Digital red+ (link 1)	
3	0 VDC	TMDS data 2/4 shield	
4	Not connected		
5	Not connected		
6	DDC clock	DDC clock	
7	DDC data	DDC data	
8	Not connected		
9	TMDS data 1-	Digital green- (link 1)	
10	TMDS data 1+	Digital green+ (link 1)	
11	0 VDC	TMDS data 1/3 shield	
12	Not connected		
13	Not connected		
14	+5 V	Power for monitor DDC interface	
15	0 V	Return for pin 14	
16	HPD	Hot plug detect	
17	TMDS data 0-	Digital blue- (link 1) and digital sync	
18	TMDS data 0+	Digital blue+ (link 1) and digital sync	
19	0 VDC	TMDS data 0/5 shield	
20	Not connected		
21	Not connected		
22	0 VDC	TMDS clock shield	
23	TMDS clock+	Digital clock+	
24	TMDS clock-	Digital clock-	
C5	Not connected		

A-3 RS-232C Connector Pin Details



The pin layout represents the RS-232C connector on the Box PC.

Pin	Signal Name
1	CD
2	RXD
3	TXD
4	DTR
5	0 VDC *1
6	DSR
7	RTS
8	CTS
9	RI
*1 Tho	0 VDC nin is internally connected to the ground connection

*1. The 0 VDC pin is internally connected to the ground connection.



Additional Information

Refer to 5-4-2 Ground on page 5-29 for grounding details.

Α



Index

Index

Α

Accessorv k	/i+															2		1 (2
ACCESSOLV	ΠL.	 	_	-	10	0													

В

2-6
7-9
7-6
A-2
2-17
5-26
5-4
4-9

С

Cables	
Communication S8BW	2-21
DVI cables	2-19
USB Type-A - USB Type-B cable	2-19
Configuration	1-5
Connect	5-42
Cooling distance	5-15
Corrective maintenance	7-5
Cover	7-6
CPU	
Intel [®] Celeron [®] 2980U	4-5

D

Dimensions	4-2
Drive	
Install	5-5
Replace	7-11
Ducts	5-25
DVI connector	2-13
Specifications	4-18

Ε

Electrical	
Specifications	
ERR LED	2-6
Ethernet connectors	2-13
Link/Act indicator	4-16
Specifications	4-15
Speed indicator	

F

Fan error	2-6
Fan Unit	
Replace	7-7

Η

2-6
2-18
4-6
4-21

<u>ا</u>

I/O connector	2-11
Connections	5-39
Specifications	
Wiring	5-39, 5-41

L

LED Indicators		2-5
----------------	--	-----

Μ

Memory Card	2-9
Memory	
Message	
Error	7-5
Warning	7-5
Monitor	2-20
Mounting	
Book mount	5-26
Brackets	2-17
Wall mount	

0

Operating system	
License key	

Ρ

PCIe Card	2-10
Install	5-9
Replace	7-16
Specifications	
Power button	
Power connector	2-11
Specifications	4-10
Wiring	5-36, 5-38
Power consumption	
Power OFF	
Forced with power button	6-4
Input signal	6-4
Operating system	6-3
Power button	6-3
Power ON	
Automatic	
Details	
First time	

Input signal	6-2
Power button	6-2
Power supply	2-20
Overvoltage error	
Undervoltage error	
Preventive maintenance	7-2
Product	1-5
PWR LED	2-5

R

RS-232C connector	2-14
Specifications	4-19
RUN LED	2-6

S

Scope of delivery SD Memory Card Software	
Update	
SSD	
Specifications	4-6
Stand-by mode	
Storage devices	2-18
Specifications	4-6

т

Temperature	. 4-21
Thermal shutdown	2-6

U

Unpack	5-2
UPS	
USB connectors	
Specifications	4-15
USB flash drives	2-18

W

Wall mount	
Wall mounting	5-27
Watchdog error	2-6
Weights	4-2
Wire	5-28
Wiring	
Warnings	5-28

Index

OMRON Corporation Kyoto, JAPAN

ion Industrial Automation Company

Contact: www.ia.omron.com

Regional Headquarters OMRON EUROPE B.V.

OMRON ELECTRONICS LLC

Wegalaan 67-69, 2132 JD Hoofddorp The Netherlands Tel: (31)2356-81-300/Fax: (31)2356-81-388

OMRON ASIA PACIFIC PTE. LTD. No. 438A Alexandra Road # 05-05/08 (Lobby 2), Alexandra Technopark, Singapore 119967 Tel: (65) 6835-3011/Fax: (65) 6835-2711 2895 Greenspoint Parkway, Suite 200 Hoffman Estates, IL 60169 U.S.A. Tel: (1) 847-843-7900/Fax: (1) 847-843-7787

OMRON (CHINA) CO., LTD. Room 2211, Bank of China Tower, 200 Yin Cheng Zhong Road, PuDong New Area, Shanghai, 200120, China Tel: (86) 21-5037-2222/Fax: (86) 21-5037-2200

Authorized Distributor:

© OMRON Corporation 2016-2019 All Rights Reserved. In the interest of product improvement, specifications are subject to change without notice.

Cat. No. W581-E2-05