

# OMRON Digital Controller

## EN INSTRUCTION MANUAL

Thank you for purchasing the OMRON E5CC-B Digital Controller. This manual describes the functions, performance, and application methods needed for optimum use of the product. Please observe the following items when using the product. The product is designed to be used by qualified personnel with a knowledge of electrical equipment.

Before using the product, thoroughly read and understand this manual to ensure correct use.

Keep this manual in a safe location so that it is available for reference whenever required.

**OMRON Corporation © All Rights Reserved**

Refer to the E5CC-C Digital Controllers User's Manual (Cat. No. H174) for detailed application procedures.

### Safety Precautions


**CAUTION** Indicates a potentially hazardous situation which, if not avoided, is likely to result in minor or moderate injury or property damage. Read this manual carefully before using the product.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

(CC-B21) 3686270-4A (Side-A)

### Wiring

#### Dimensions




Do not remove the terminal block. Doing so may result in failure or malfunction.

A Setup Tool port is provided on the upper of the product. Use this port to connect a personal computer to the product when using the Setup Tool. E50-CIF02 USB-Serial Conversion Cable is required to connect the personal computer to the product. (Do not use the Setup Tool port with the E50-CIF02 USB-Serial Conversion Cable left permanently connected.)

Refer to the E50-CIF02 USB-Serial Conversion Cable for details on connection methods.

Names of Parts on Front Panel



### Operation Menu

#### Input Type

	Input	Setting	Setting range
Platinum resistance thermometer	Pt100	0 ~ -200 to 850	-300 ~ 1500
		2 ~ 0 to 1000	0 ~ 1000
JPt100	3 ~ -199.5 to 500	-199.5 ~ 9000	
Thermocouple	K	-200 ~ 1300	-300 ~ 2300
	E	-20 ~ 200 to 500	0 ~ 500
J	8 ~ -20 to 400	0 ~ 750	
T	-200 ~ 200 to 400	-300 ~ 700	
	U	10 ~ 200 to 400	0 ~ 1000
E	11 ~ 200 to 600	300 ~ 1100	
U	6 ~ 200 to 1200	0 ~ 1500	
N	14 ~ 199.5 to 400	-199.5 ~ 700.0	
R	15 ~ 200 to 300	-300 ~ 2300	
S	17 ~ 0 to 1700	0 ~ 3000	
W	18 ~ 100 to 1800	300 ~ 2300	
Platinum resistance thermometer	Pt_II	20 ~ 0 to 3000	0 ~ 2300
Thermocouple	T	20 ~ 0 to 120	0 ~ 240
E51B	115 ~ 165°C	23 ~ 165	
Current input	0 ~ 20mA	Use the following ranges for scaling: -1999 ~ 1999, -199.9 ~ 1999, 0 ~ 10V	-199.9 ~ 1999, 0 ~ 10V
Voltage input	0 ~ 10V	Use the following ranges for scaling: -1999 ~ 1999, -199.9 ~ 1999, 0 ~ 10V	-199.9 ~ 1999, 0 ~ 10V

The default is “C”. The value will be displayed when a platinum resistance thermometer is mistakenly connected while input type is not set. To clear the SEPP display, contact the company and copy the power supply.

#### Alarms (Alarms are output from auxiliary outputs.)

Setting	Alarm type	Alarm output function
0	No alarm function	Positive alarm value (X) Negative alarm value (X)
1	Deviation upper/lower limit	ON: Output off
2	Deviation upper limit	Vary with “L” values
3	Deviation lower limit	ON: Output off
4	Deviation upper/lower range	ON: Output off Vary with “L” values
5	Deviation upper/lower limit sequence ON	ON: Output off
6	Deviation upper limit sequence ON	ON: Output off
7	Deviation lower limit sequence ON	ON: Output off
8	Absolute value upper limit	ON: Output off
9	Absolute value lower limit	ON: Output off
10	Absolute value upper limit sequence ON	ON: Output off
11	Absolute value lower limit sequence ON	ON: Output off
12	LBA (only for alarm 1)	ON: Output off
13	SP Change Rate Alarm	ON: Output off
14	SP absolute value upper limit	ON: Output off
15	SP absolute value lower limit	ON: Output off
16	MV absolute value upper limit	ON: Output off
17	MV absolute value lower limit	ON: Output off

\*1: Upper and lower limits can be set for parameters 1, 4 and 5 to provide for different types of alarm. These are indicated by “L” and “H”.

\*2: The default alarm type is “C”.

#### Performance to EN/IEC Standards

This is a class A product.

In residential areas it may cause radio interference, in which case the user may be required to take adequate measures to reduce interference.

이 기기는 무선설비를瓈정하여 판매되며, 사용자는 이 점을 주의하시기 바라며, 기기의 설치 위치에 따라 차단기 또는 방지 장치가 필요할 수 있습니다.

#### Conformance to Safety Standard

Reinforced insulation is provided between input power supply, relay outputs, and between other terminals.

Due to UL Listing requirements, use the E54-CT1L or E54-CT3L current transformer with the flat-blade screwdriver or XGBA-100A7 current transformer that is supplied for field wiring (external wiring).

Always externally connect the recommended fuse that is specified in the Instruction Manual.

Analog Input

If an input is analog voltage or current, set the Input Type parameter to the correct input type.

To prevent short circuits, insert the stripped part of the wire into the terminal block to conductive parts of a ferrule until it is hidden inside the terminal insertion hole. (See the following diagram.)

If a wire is difficult to connect because it is too thin, use a flat-blade screwdriver in the same way as when connecting stranded wire.

The protection provided by the Digital Controller may be impaired if the Digital Controller is used in a manner that is not specified by the manufacturer.

### Warning Symbols

#### CAUTION

Minor injury due to electric shock may occasionally occur.

Do not touch the terminals while power is being supplied.

Electric shock, fire, or malfunction may occasionally occur. Do not allow metal objects, conductors, cuttings from installation work, or moisture to enter the Digital Controller, the Setup Tool port, or between the Digital Controller and the Setup Tool cable.

Do not use the product when subject to flameable gases, otherwise, minor injury from explosion may occasionally occur.

CAUTION - Risk of Fire and Electric Shock

a) If the product UL listed as Open Type Process Control Equipment. It must be mounted in an enclosure.

b) More than one disconnect switch may be required to de-energize the equipment before servicing.

c) Signal limited energy.

d) Caution: To reduce the risk of fire or electric shock, do not disconnect the outputs of different Class 2 circuits.

e) The Digital Controller is a Class 2 product.

f) Make sure that the output voltage is within two seconds of turning on the power using a switch or relay contact. If the output voltage is not within two seconds of turning on the power using a switch or relay contact, the output voltage may occur.

g) Make sure that the Digital Controller has 30 minutes or more to warm up after turning on 100.0 operations.

h) When executing self-start, turn the load and the unit ON simultaneously.

i) Make sure to wire properly with correct terminal name and polarity of terminals.

j) Use a flat-blade screwdriver.

k) Do not use wires longer than 1.5 m (equivalent to AWG24 to AWG16).

l) Do not use wires longer than 10 mm if ferrules are used and 8 mm if crimp sleeves are used.

m) Do not wire the terminals which are not used.

n) Do not use the terminals which are not used.

o) Do not use the terminals which are not used.

p) Do not use the terminals which are not used.

q) Do not use the terminals which are not used.

r) Do not use the terminals which are not used.

s) Do not use the terminals which are not used.

t) Do not use the terminals which are not used.

u) Do not use the terminals which are not used.

v) Do not use the terminals which are not used.

w) Do not use the terminals which are not used.

x) Do not use the terminals which are not used.

y) Do not use the terminals which are not used.

z) Do not use the terminals which are not used.

aa) Do not use the terminals which are not used.

bb) Do not use the terminals which are not used.

cc) Do not use the terminals which are not used.

dd) Do not use the terminals which are not used.

ee) Do not use the terminals which are not used.

ff) Do not use the terminals which are not used.

gg) Do not use the terminals which are not used.

hh) Do not use the terminals which are not used.

ii) Do not use the terminals which are not used.

jj) Do not use the terminals which are not used.

kk) Do not use the terminals which are not used.

ll) Do not use the terminals which are not used.

mm) Do not use the terminals which are not used.

nn) Do not use the terminals which are not used.

oo) Do not use the terminals which are not used.

pp) Do not use the terminals which are not used.

qq) Do not use the terminals which are not used.

rr) Do not use the terminals which are not used.

ss) Do not use the terminals which are not used.

tt) Do not use the terminals which are not used.

uu) Do not use the terminals which are not used.

vv) Do not use the terminals which are not used.

ww) Do not use the terminals which are not used.

xx) Do not use the terminals which are not used.

yy) Do not use the terminals which are not used.

zz) Do not use the terminals which are not used.

aa) Do not use the terminals which are not used.

bb) Do not use the terminals which are not used.

cc) Do not use the terminals which are not used.

dd) Do not use the terminals which are not used.

ee) Do not use the terminals which are not used.

ff) Do not use the terminals which are not used.

gg) Do not use the terminals which are not used.

hh) Do not use the terminals which are not used.

ii) Do not use the terminals which are not used.

jj) Do not use the terminals which are not used.

kk) Do not use the terminals which are not used.

ll) Do not use the terminals which are not used.

mm) Do not use the terminals which are not used.

nn) Do not use the terminals which are not used.

oo) Do not use the terminals which are not used.

pp) Do not use the terminals which are not used.

qq) Do not use the terminals which are not used.

rr) Do not use the terminals which are not used.

